

## **Appendix C.1 General Emissions Calculations**

Desert View Power  
2021 Emissions Performance Test

## GENERAL EMISSIONS CALCULATIONS

### I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \% CO_2 + 0.32 * \% O_2 + 0.28 * \% N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 - 28.95}{P_s * MW_{wet}}}$$

### II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * \left( P_{bar} + \frac{\Delta H}{13.6} \right) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{ic} * \frac{T_{ref}}{528^{\circ}R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

### III. Stack Gas Volumetric Flow Rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

Desert View Power  
2021 Emissions Performance Test

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * \text{MW}_i * Q_{sd} * 60}{\text{SV} * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * \text{MW}_i * F}{\text{SV} * 10^6} * \frac{20.9}{20.9 - \% \text{ O}_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{mstd})}{(1 - B_{wo}) 0 * V_s * P_s * Dn^2} * \frac{520^\circ R}{T_{ref}}$$

VII. Particulate Emissions

(a) Grain loading, gr/dscf  
 $C = 0.01543 (M_n/V_m \text{ std})$

(b) Grain loading at 12% CO<sub>2</sub>, gr/dscf  
 $C_{12\% \text{ CO}_2} = C (12\% \text{ CO}_2)$

(c) Mass emissions, lb/hr  
 $M = C * Q_{sd} * (60 \text{ min/hr}) / (7000 \text{ gr/lb})$

(d) Particulate emission factor

$$\text{lb}/10^6 \text{ Btu} = Cx \frac{1 \text{ lb}}{7000 \text{ gr}} * F * \frac{20.9}{20.9 - \% \text{ O}_2}$$

Desert View Power  
2021 Emissions Performance Test

Nomenclature:

$A_s$	=	stack area, ft <sup>2</sup>
$B_{wo}$	=	flue gas moisture content, dimensionless
$C_{12\%CO_2}$	=	particulate grain loading, gr/dscf corrected to 12% CO <sub>2</sub>
$C$	=	particulate grain loading, gr/dscf
$C_p$	=	pitot calibration factor, dimensionless
$D_n$	=	nozzle diameter, inches
$F$	=	fuel F-Factor, dscf/MMBtu @ 0% O <sub>2</sub>
$H$	=	orifice differential pressure, iwg
$I$	=	% isokinetics
$M_n$	=	mass of collected particulate, mg
$M_i$	=	mass emission rate of specie i, lb/hr
$MW$	=	molecular weight of flue gas, lb/lb-mole
$M_{wi}$	=	molecular weight of specie i: SO <sub>2</sub> : 64 NO <sub>x</sub> : 46 CO: 28 HC: 16
$t$	=	sample time, minutes
$\Delta P$	=	average velocity head, iwg = $(\sqrt{\Delta P})^2$
$P_{bar}$	=	barometric pressure, inches Hg
$P_s$	=	stack absolute pressure, inches Hg
$P_{sg}$	=	stack static pressure, iwb
$Q$	=	wet stack flow rate at actual conditions, wacfm
$Q_{sd}$	=	dry standard stack flow rate, dscfm
$SV$	=	specific molar volume of an ideal gas at standard conditions, ft <sup>3</sup> /lb-mole
$T_m$	=	meter temperature, °R
$T_{ref}$	=	reference temperature, °R
$T_s$	=	stack temperature, °R
$V_s$	=	stack gas velocity, ft/sec
$V_{lc}$	=	volume of liquid collected in impingers, ml
$V_m$	=	uncorrected dry meter volume, dcf
$V_{mstd}$	=	dry meter volume at standard conditions, dscf
$V_{wstd}$	=	volume of water vapor at standard conditions, scf
$Y_d$	=	meter calibration coefficient

## **Appendix C.2 Unit 1 Calculations**

## **Appendix C.2.1**

### **Unit 1 Gaseous Calculations**

**Montrose AQ\$**  
**RELATIVE ACCURACY TEST AUDIT**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA			METHOD 2 DATA			
GENERAL				Impingers			dP		dP <sup>2</sup>	Temp
Test:	1-RA-U1	#/Matl.	End	Start	Diff.	Point	(in. H <sub>2</sub> O)	(in. H <sub>2</sub> O <sup>2</sup> )	(°F)	(fps)
Date:	3/10/2021	1/H <sub>2</sub> O	910.8	731.4	179.4	5	1.10	1.0488	357	73.32
Start Time:	7:46	2/H <sub>2</sub> O	711.1	710.4	0.7	4	0.98	0.9899	358	69.25
Station:	Desert View Power	3/Empty	638.4	638.4	0.0	3	0.84	0.9165	360	64.19
Unit:	#1	4/S.G.	866.9	857.1	9.8	2	1.00	1.0000	360	70.04
Test Condition:	Full Load	Rinse		50.0	-50.0	1	0.95	0.9747	358	68.18
Performed By:	DW	Total			139.9	5	1.40	1.1832	357	82.72
PRE-TEST INFORMATION				Dry Gas Meter			dP		dP <sup>2</sup>	Temp
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)			(°F)
Barom. Pressure:		psi	"Hg	Start	660.100	60	61			
	30.11					61	62			
Meter No.	1 P&M			Stop	698.957	62	64			
Meter Y <sub>d</sub>	1.0110									
Meter Pressure:	1.5	iwg		Total	38.857		61.7			
Pstack:	0.48	iwg								
Pstack:	30.14	"Hg								
Cp:	0.84			Sample Volume:	40.153	dscf				
Tref:	68	°F		H <sub>2</sub> O Volume :	6.603	scf				
Stack Area:	38.84	ft <sup>2</sup>		Moisture Content:	14.1	%				
METHOD 3A, 6C, 7E DATA				Summary			dP		dP <sup>2</sup>	Temp
O <sub>2</sub>	CO <sub>2</sub>	NO <sub>x</sub>	CO	Summary						
Analyzer Span	19.15	18.94	87.00	9.64			5	1.40	1.1832	357
Actual Span Value	10.78	10.56	41.3	4.6			4	1.20	1.0954	358
Pre Test Zero Direct	0.01	0.01	0.02	0.01			3	1.30	1.1402	359
Pre Test Span Direct	10.87	10.43	41.49	4.61			2	1.20	1.0954	358
Pre-test Zero	0.04	0.11	0.06	0.12			1	1.00	1.0000	358
Pre-test Span	10.84	10.44	41.21	4.61			5	1.40	1.1832	357
0-30 min	9.10	11.60	35.05	0.24			4	1.40	1.1832	358
Post Test Zero Direct	0.01	0.03	0.02	0.03			3	1.30	1.1402	356
Post Test Span Direct	10.87	10.47	41.46	4.65			2	1.20	1.0954	358
Post-test Zero	0.03	0.11	0.04	0.14			1	1.10	1.0488	357
Post-test Span	10.84	10.52	41.19	4.64			Average	1.0747	1.0367	357.9
Average	9.10	11.60	35.05	0.24						72.51
Corr. Results	9.04	11.70	35.13	0.12						
Cal Error <2%, Bias <5%; Drift <3%										
Calibration Error	0.5%	-0.7%	0.2%	0.1%						
Pre-Test Zero Bias	0.2%	0.5%	0.1%	1.1%						
Pre-Test Span Bias	-0.2%	0.1%	-0.3%	0.0%						
Post-Test Zero Bias	0.1%	0.4%	0.0%	1.1%						
Post-Test Span Bias	-0.2%	0.3%	-0.3%	-0.1%						
Zero Drift	-0.1%	0.0%	0.0%	0.2%						
Span Drift	0.0%	0.5%	0.0%	0.4%						
<b>CAL STATUS</b>	<b>PASS</b>	<b>PASS</b>	<b>PASS</b>	<b>PASS</b>						
RELATIVE ACCURACY DATA										
Parameter	Units	Ref. Meth	CEMS		Diff.	Diff. %				
Flow	kdscfh	5662.65	5986.87		-324.21	-5.7%				
O <sub>2</sub>	% dry	9.04	9.2		-0.12	-1.4%				
CO <sub>2</sub>	% dry	11.70	11.5		0.16	1.3%				
NO <sub>x</sub>	ppm dry	35.13	37.1		-1.97	-5.6%				
NO <sub>x</sub>	ppm @ 3% O <sub>2</sub>	53.02	56.1		-3.09	-5.8%				
NO <sub>x</sub>	lb/hr	23.75	26.66		-2.91	-12.2%				
SO <sub>2</sub>	ppm dry	5.97	6.21		-0.25	-4.1%				
SO <sub>2</sub>	ppm @ 3% O <sub>2</sub>	9.01	9.40		-0.40	-4.4%				
SO <sub>2</sub>	lb/hr	5.61	6.198		-0.585	-10.4%				
CO	ppm dry	0.12	1.19		-1.07					
CO	ppm @ 3% O <sub>2</sub>	0.18	1.82		-1.64					
CO	lb/hr	0.050	0.518		-0.47					
TEST SUMMARY										
O <sub>2</sub> :		9.040								
		7.764								
CO <sub>2</sub> :		11.700								
		10.047								
NO <sub>x</sub> :		35.130								
		30.169								
		23.750								
SO <sub>2</sub> :		5.9667267								
		5.612								
H <sub>2</sub> O:		14.1								
MW:		28.51								
Flow:		168.989								
		94.38								
		5662.65								
SOx Titration Summary										
B1/2		Probe								
N BaCl <sub>2</sub>		0.0096712								
Total VOL (ml)		511.9								
Aliquot VOL (ml)		20								
Titrant VOL (ml)		2.28								

**Montrose AQ**  
**RELATIVE ACCURACY TEST AUDIT**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION		METHOD 4 DATA			METHOD 2 DATA					
GENERAL		Impingers			Point	dP (in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	Temp (°F)	Velocity (fps)	
Test:	2-RA-U1	#/Matl.	End	Start	Diff.	5	1.20	1.0954	362	76.92
Date:	3/10/2021	1/H <sub>2</sub> O	845.9	655.2	190.7	4	1.00	1.0000	364	70.31
Start Time:	9:08	2/H <sub>2</sub> O	730.0	728.6	1.4	3	0.98	0.9899	365	69.64
Station:	Desert View Power	3/Empty	592.9	591.9	1.0	2	1.00	1.0000	366	70.39
Unit:	#1	4/S.G.	896.3	881.1	15.2	1	0.96	0.9798	368	69.05
Test Condition:	Full Load	Rinse		50.0	-50.0					
Performed By:	DW	Total			158.3					
PRE-TEST INFORMATION		Dry Gas Meter			Summary					
SAMPLE TRAIN		Time	Vol.	Tm(in)	Tm(out)	Sample Volume:	43.332	dscf		
Barom. Pressure:	30.11	Start	700.100	70	71	H <sub>2</sub> O Volume :	7.472	scf		
Meter No.	1 P&M	Stop	743.024	75	78	Moisture Content:	14.7	%		
Meter Y <sub>d</sub> :	1.0110	Total	42.924		74.0					
Meter Pressure:	1.5	iwg								
Pstack:	0.48	iwg								
Pstack:	30.14	"Hg								
Cp:	0.84									
Tref:	68	°F								
Stack Area:	38.84	ft <sup>2</sup>								
METHOD 3A, 6C, 7E DATA					TEST SUMMARY					
		O <sub>2</sub>	CO <sub>2</sub>	NO <sub>x</sub>	CO	O <sub>2</sub>	9.031	% dry		
Analyzer Span		19.15	18.94	87.00	9.64		7.703	% wet		
Actual Span Value		10.78	10.56	41.3	4.60					
Pre Test Zero Direct		0.01	0.03	0.02	0.03	CO <sub>2</sub>	11.648	% dry		
Pre Test Span Direct		10.87	10.47	41.46	4.65		9.935	% wet		
Pre-test Zero		0.03	0.11	0.04	0.14	NO <sub>x</sub>	34.221	ppm dry		
Pre-test Span		10.84	10.52	41.19	4.64		29.188	ppm wet		
0-30 min		9.06	11.45	34.11	0.25		23.286	lb/hr		
Post Test Zero Direct		0.00	-0.03	0.02	-0.01	SO <sub>2</sub>	6.733102	ppm dry		
Post Test Span Direct		10.82	10.23	41.40	4.56					
Post-test Zero		0.02	0.03	0.07	0.11					
Post-test Span		10.78	10.25	41.13	4.55					
Average		9.06	11.45	34.11	0.25					
Corr. Results		9.03	11.65	34.22	0.13					
Cal Error <2%, Bias <5%; Drift <3%										
Calibration Error		0.5%	-0.5%	0.2%	0.6%					
Pre-Test Zero Bias		0.1%	0.4%	0.0%	1.1%					
Pre-Test Span Bias		-0.2%	0.3%	-0.3%	-0.1%					
Post-Test Zero Bias		0.1%	0.3%	0.1%	1.2%					
Post-Test Span Bias		-0.2%	0.1%	-0.3%	-0.1%					
Zero Drift		0.0%	-0.4%	0.0%	-0.3%					
Span Drift		-0.3%	-1.4%	-0.1%	-0.9%					
<b>CAL STATUS</b>		<b>PASS</b>	<b>PASS</b>	<b>PASS</b>	<b>PASS</b>					
RELATIVE ACCURACY DATA										
Parameter	Units	Ref. Meth	CEMS	Diff.	Diff. %					
Flow	kdscfh	5699.54	5988.87	-289.33	-5.1%		6.374	lb/hr		
O <sub>2</sub>	% dry	9.03	9.2	-0.12	-1.3%					
CO <sub>2</sub>	% dry	11.65	11.5	0.13	1.1%	CO:	0.13	ppm dry		
NO <sub>x</sub>	ppm dry	34.22	36.1	-1.88	-5.5%		0.11	ppm wet		
NO <sub>x</sub>	ppm @ 3% O <sub>2</sub>	51.61	54.6	-3.03	-5.9%					
							0.055	lb/hr		
NO <sub>x</sub>	lb/hr	23.29	25.9	-2.65	-11.4%	H <sub>2</sub> O:	14.7	%		
SO <sub>2</sub>	ppm dry	6.73	6.94	-0.21	-3.1%	MW:	28.43	lb/lb-mole		
SO <sub>2</sub>	ppm @ 3% O <sub>2</sub>	10.15	10.52	-0.37	-3.6%	Flow:	173,350	wacf m		
							94.992	mdscfm		
							5699.54	kdscfh		
SOx Titration Summary										
SO <sub>2</sub>	lb/hr	6.374	6.921	-0.546	-8.6%		B1/2	Probe		
CO	ppm dry	0.13	0.32	-0.18		N BaCl <sub>2</sub>	0.0096712			
CO	ppm @ 3% O <sub>2</sub>	0.20	0.48	-0.28		Total VOL (ml)	513.1			
CO	lb/hr	0.055	0.142			Aliquot VOL (ml)	20			
						Titrant VOL (ml)	2.77			

**Montrose AQTS  
RELATIVE ACCURACY TEST AUDIT  
DATA AND WORKSHEET  
Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA						
GENERAL				Impingers			dP			Temp	Velocity			
Test:	3-RA-U1			#/Matl.	End	Start	Diff.	Point	(in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	(°F)	(fps)		
Date:	3/10/2021			1/H <sub>2</sub> O	927.7	737.1	190.6	5	1.30	1.1402	371	80.48		
Start Time:	10:34			2/H <sub>2</sub> O	712.6	711.1	1.5	4	0.99	0.9950	372	70.28		
Station:	Desert View Power			3/Empty	639.9	639.6	0.3	3	0.98	0.9899	373	69.96		
Unit:	#1			4/S.G.	877.0	866.9	10.1	2	1.10	1.0488	372	74.08		
Test Condition:	Full Load			Rinse		50.0	-50.0	1	0.97	0.9849	371	69.52		
Performed By:	DW			Total			152.5	5	1.40	1.1832	370	83.47		
PRE-TEST INFORMATION				Dry Gas Meter			dP			Temp	Velocity			
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)	Point	(in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	(°F)	(fps)		
Barom. Pressure:	30.11 "Hg			Start	745.000	73	76	5	1.30	1.1402	371	80.48		
Meter No.	1 P&M					74	77	4	0.94	0.9695	372	68.48		
Meter Y <sub>d</sub> :	1.0110			Stop	786.418	78	78	3	0.97	0.9849	371	69.52		
Meter Pressure:	1.5 iwg			Total	41.418		76.0	2	0.92	0.9055	372	63.96		
Pstack:	0.48 iwg			Summary				1	0.82					
Pstack:	30.14 "Hg			Sample Volume:	41.655	dscf		5	0.96	0.9798	371	69.16		
Cp:	0.84			H <sub>2</sub> O Volume :	7.198	scf		4	0.99	0.9950	372	70.28		
Tref:	68 °F			Moisture Content:	14.7	%		3	0.93	0.9644	372	68.11		
Stack Area:	38.84 ft <sup>2</sup>							2	0.92	0.9592	371	67.71		
	METHOD 3A, 6C, 7E DATA							1	1.10	1.0488	372	74.08		
	O <sub>2</sub>	CO <sub>2</sub>	NO <sub>x</sub>	CO				5	1.10	1.0488	371	74.03		
Span	19.15	18.94	87.00	9.64				1	1.20	1.0954	372	77.37		
Actual Span Value	10.78	10.56	41.3	4.60				4	1.20	1.0954	371	77.33		
Pre Test Zero Direct	0.00	-0.03	0.02	-0.01				3	1.30	1.1402	372	80.53		
Pre Test Span Direct	10.82	10.23	41.40	4.56				2	1.20	1.0954	371	77.33		
Pre-test Zero	0.02	0.03	0.07	0.11				1	1.10	1.0488	370	73.99		
Pre-test Span	10.78	10.25	41.13	4.55				5	1.40	1.1832	369	83.42		
0-30 min	8.84	11.34	39.62	0.17				4	1.30	1.1402	370	80.44		
Post Test Zero Direct	-0.01	-0.03	0.04	-0.06				3	1.20	1.0954	371	77.33		
Post Test Span Direct	10.75	10.04	41.24	4.43				2	1.20	1.0954	370	73.99		
Post-test Zero	0.01	0.04	0.08	0.08				1	1.10	1.0488	370	75.04		
Post-test Span	10.72	10.04	40.88	4.42				Average	1.1297	1.0629	371.2			
Average	8.84	11.34	39.62	0.17										
Corr. Results	8.86	11.80	39.91	0.08										
Cal Error <2%, Bias <5%, Drift <3%														
Calibration Error	0.2%	-1.8%	0.1%	-0.4%										
Pre-Test Zero Bias	0.1%	0.3%	0.1%	1.2%										
Pre-Test Span Bias	-0.2%	0.1%	-0.3%	-0.1%										
Post-Test Zero Bias	0.1%	0.3%	0.0%	1.5%										
Post-Test Span Bias	-0.2%	0.0%	-0.4%	-0.1%										
Zero Drift	0.0%	0.1%	0.0%	-0.3%										
Span Drift	-0.3%	-1.1%	-0.3%	-1.3%										
CAL STATUS	PASS	PASS	PASS	PASS										
RELATIVE ACCURACY DATA														
Parameter	Units	Ref. Meth	CEMS	Diff.	Diff. %									
Flow	kdscfh	5724.72	5089	635.62	11.1%									
O <sub>2</sub>	% dry	8.86	9.0	-0.13	-1.5%									
CO <sub>2</sub>	% dry	11.80	11.7	0.14	1.2%									
NO <sub>x</sub>	ppm dry	39.91	41.6	-1.66	-4.2%									
NO <sub>x</sub>	ppm @ 3% O <sub>2</sub>	59.32	62.1	-2.75	-4.6%									
						0.033	lb/hr							
NO <sub>x</sub>	lb/hr	27.27	25.33	1.94	7.1%	H <sub>2</sub> O:	14.7	%						
SO <sub>2</sub>	ppm dry	7.41	8.20	-0.78	-10.6%	MW:	28.44	lb/lb-mole						
SO <sub>2</sub>	ppm @ 3% O <sub>2</sub>	11.02	12.21	-1.19	-10.8%	Flow:	174,864	wacf m						
							95.41	mdscfm						
							5724.72	kdscfh						
SOx Titration Summary														
SO <sub>2</sub>	lb/hr	7.049	7.004	0.045	0.6%	B1/2	Probe							
CO	ppm dry	0.08	0.77	-0.69		N BaCl <sub>2</sub>	0.0096712							
CO	ppm @ 3% O <sub>2</sub>	0.12	1.15	-1.04		Total VOL (ml)	503.1							
CO	lb/hr	0.033	0.288	-0.26		Aliquot VOL (ml)	20							
						Titrant VOL (ml)	2.99							

## **Appendix C.2.2**

### **Unit 1 Hydrogen Chloride Calculations**

**HCL**  
**Desert View Power - Unit 1**

Test No	1-HCl	2-HCl	3-HCl	Average	Limit
Date	3/5/2021	3/5/2021	3/5/2021		
Start Time	7:20	9:42	12:10		
Stop Time	9:20	11:42	14:10		

---

Test Information

---

Reference Temperature, °F	68	68	68
---------------------------	----	----	----

---

Diluent Emissions and Stack Flow Rate

---

Moisture Fraction, %	13.1	12.5	13.7	13.1
O <sub>2</sub> , % vol. dry	9.01	9.00	8.92	8.98
CO <sub>2</sub> , % vol. Dry	11.61	11.66	11.72	11.66
Stack Flow Rate (dscfm)	92,396	93,518	92,706	92,873
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 68°.....	9,240	9,240	9,240	
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 60°.....	9,100	9,100	9,100	

---

HCl Emissions

---

ppmvw	12.16	10.28	10.07	10.84
ppmvd	14.00	11.75	11.66	12.47
lb/hr (as HCl)	7.5	6.3	6.2	6.68
lb/MMBtu	0.0215	0.0181	0.0178	0.019 <b>0.022</b>

---

**Montrose AQ\$**  
**Run 1 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA							
GENERAL				Impingers											
Test:	1-O2/CO2-U1			#/Matl.	End	Start	Diff.	Point	dP (in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	Temp (°F)	Velocity (fps)			
Date:	3/5/2021			1/H <sub>2</sub> O	898.9	742.1	156.8	5	1.30	1.1402	358	79.38			
Start Time:	7:20			2/H <sub>2</sub> O	722.5	651.6	70.9	4	0.98	0.9899	359	68.96			
Station:	Desert View Power			3/Empty	666.1	660.2	5.9	3	0.64	0.8000	354	55.56			
Unit:	Unit 1			4/S.G.	964.0	936.0	28.0	2	1.00	1.0000	355	69.49			
Test Condition:	Full Load			Rinse			0.0	1	0.99	0.9950	352	69.02			
Performed By:	RD			Total			261.6	5	1.40	1.1832	356	82.27			
PRE-TEST INFORMATION				Dry Gas Meter				4	1.00	1.0000	358	69.62			
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)	3	0.92	0.9592	357	66.74			
Barom. Pressure:	psi			Start	103.200	60	60	2	0.68	0.8246	352	57.20			
	30.28 "Hg					64	62	1	0.66	0.8124	351	56.32			
Meter No.	30-WCS			Stop	184.177	66	63	5	0.87	0.9327	353	64.74			
Meter Y <sub>d</sub> :	0.9830			Total	80.977		62.5	4	0.83	0.9110	352	63.19			
Meter Pressure:	1.5	iwg		Summary				3	0.80	0.8944	354	62.12			
Pstack:	0.53	iwg		Sample Volume: 81.689 dscf				2	0.91	0.9539	355	66.29			
Pstack:	30.32	"Hg		H <sub>2</sub> O Volume : 12.348 scf				1	0.93	0.9644	356	67.06			
Cp:	0.84			Moisture Content: 13.1 %				5	1.40	1.1832	357	82.33			
Tref:	68	°F						4	1.10	1.0488	358	73.02			
Stack Area:	38.84	ft <sup>2</sup>						3	0.84	0.9165	357	63.77			
METHOD 3A, 6C, 7E DATA								2	0.82	0.9055	355	62.93			
<u>O<sub>2</sub></u> <u>CO<sub>2</sub></u>								1	0.80	0.8944	354	62.12			
Analyzer Span	19.15	18.94						5	1.30	1.1402	352	79.09			
Actual Span Value	10.78	10.56						4	1.10	1.0488	353	72.79			
Pre Test Zero Direct	0.00	0.00						3	1.00	1.0000	354	69.45			
Pre Test Span Direct	10.84	10.39						2	1.10	1.0488	355	72.88			
Pre-test Zero	0.14	0.04						1	1.00	1.0000	352	69.36			
Pre-test Span	10.88	10.32						5	1.40	1.1832	353	82.12			
Average	9.08	11.40						4	1.30	1.1402	354	79.18			
Post Test Zero Direct	0.00	-0.01						3	1.30	1.1402	356	79.28			
Post Test Span Direct	10.87	10.43						2	1.00	1.0000	357	69.58			
Post-test Zero	0.03	0.08						1	1.00	1.0000	355	69.49			
Post-test Span	10.80	10.44						Average	1.0007	1.0004	354.8	69.51			
Average	9.08	11.40						TEST SUMMARY							
Corr. Results	9.01	11.61						O <sub>2</sub> :	9.012	% dry					
Cal Error <2%, Bias <5%; Drift <3%									7.829	% wet					
Calibration Error	0.3%	-0.9%						CO <sub>2</sub> :	11.610	% dry					
Pre-Test Zero Bias	0.7%	0.2%							10.086	% wet					
Pre-Test Span Bias	0.2%	-0.4%						H <sub>2</sub> O:	13.1	%					
Post-Test Zero Bias	0.1%	0.5%						MW:	28.61	lb/lb-mole					
Post-Test Span Bias	-0.4%	0.0%						Flow:	161,992	wacfm					
Zero Drift	-0.6%	0.2%							92.40	mdscfm					
Span Drift	-0.4%	0.6%							5543.75	kdscfh					

**Montrose AQS**  
**Run 2 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA				
GENERAL				Impingers				dP		dP'	Temp (°F)	Velocity (fps)
Test:	2-O2/CO2-U1	#/Matl.	End	Start	Diff.		Point					
Date:	3/5/2021	1/H2O	991.6	812.9	178.7		5	1.40	1.1832	356	82.16	
Start Time:	9:42	2/H2O	807.5	734.2	73.3		4	1.20	1.0954	357	76.11	
Station:	Desert View Power	3/Empty	588.2	586.7	1.5		3	1.30	1.1402	358	79.27	
Unit:	Unit 1	4/S.G.	1035.9	1034.5	1.4		2	1.10	1.0488	356	72.83	
Test Condition:	Full Load	Rinse			0.0		1	1.00	1.0000	355	69.40	
Performed By:	RD	Total			254.9		5	1.20	1.0954	354	75.97	
PRE-TEST INFORMATION				Dry Gas Meter				4	1.10	1.0488	356	72.83
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)	3	1.00	1.0000	357	69.48
Barom. Pressure:	psi	Start	490.000	74	76		2	1.00	1.0000	358	69.52	
	"Hg			77	80		1	1.10	1.0488	359	72.96	
Meter No.	1 P&M	Stop	573.448	81	84		5	1.30	1.1402	354	79.08	
	1.0110						4	1.20	1.0954	355	76.02	
Meter Pressure:	1.5	iwg	Total	83.448		78.7		3	0.86	0.9274	355	64.36
Pstack:	0.53	iwg					2	0.84	0.9165	356	63.64	
Pstack:	30.32	"Hg	Sample Volume:	83.981	dscf		1	0.80	0.8944	356	62.11	
Cp:	0.84			12.031	scf		5	0.91	0.9539	359	66.36	
Tref:	68	°F	Moisture Content:	12.5	%		4	0.84	0.9165	356	63.64	
Stack Area:	38.84	ft2		3			3	0.82	0.9055	358	62.96	
METHOD 3A, 6C, 7E DATA							2	0.89	0.9434	359	65.63	
							1	0.91	0.9539	354	66.16	
Analyzer Span	19.15	18.94					5	1.30	1.1402	352	78.98	
Actual Span Value	10.78	10.56					4	1.00	1.0000	353	69.31	
Pre Test Zero Direct	0.00	-0.01					3	0.98	0.9899	354	68.66	
Pre Test Span Direct	10.87	10.43					2	0.72	0.8485	355	58.88	
Pre-test Zero	0.03	0.08					1	0.69	0.8307	356	57.68	
Pre-test Span	10.80	10.44					5	1.40	1.1832	354	82.06	
Average	8.99	11.38					4	0.98	0.9899	355	68.70	
							3	0.92	0.9592	356	66.60	
Post Test Zero Direct	0.00	-0.02					2	0.99	0.9950	355	69.05	
Post Test Span Direct	10.77	10.18					1	0.97	0.9849	356	68.39	
Post-test Zero	0.03	0.08					Average	1.0154	1.0076	355.8	69.96	
Post-test Span	10.73	10.19										
Average	8.99	11.38										
Corr. Results	9.00	11.66										
Cal Error <2%, Bias <5%, Drift <3%												
Calibration Error	0.5%	-0.7%										
Pre-Test Zero Bias	0.1%	0.5%										
Pre-Test Span Bias	-0.4%	0.0%										
Post-Test Zero Bias	0.1%	0.5%										
Post-Test Span Bias	-0.2%	0.1%										
Zero Drift	0.0%	0.0%										
Span Drift	-0.4%	-1.3%										

**Montrose AQ**  
**Run 3 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA			
GENERAL				Impingers			Point	dP	dP'	Temp	Velocity
Test:	3-O2/CO2-U1	#/Matl.	End	Start	Diff.			(°F)	(fps)		
Date:	3/5/2021	1/H2O	927.6	755.0	172.6	5	1.30	1.1402	356	79.36	
Start Time:	12:10	2/H2O	724.4	647.6	76.8	4	0.96	0.9798	357	68.24	
Station:	Desert View Power	3/Empty	668.9	666.1	2.8	3	0.90	0.9487	358	66.11	
Unit:	Unit 1	4/S.G.	973.2	950.3	22.9	2	0.95	0.9747	357	67.88	
Test Condition:	Full Load	Rinse			0.0	1	0.95	0.9747	356	67.84	
Performed By:	RD	Total			275.1	5	1.40	1.1832	357	82.40	
PRE-TEST INFORMATION				Dry Gas Meter							
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)				
Barom. Pressure:	30.28	psi	"Hg	Start	575.000	86	88				
Meter No.	1 P&M					90	92				
.....	1.0110			Stop	658.337	94	96				
Meter Pressure:	1.5	iwg		Total	83.337		91.0				
Pstack:	0.53	iwg		Summary							
Pstack:	30.32	"Hg		Sample Volume:	81.992	dscf					
Cp:	0.84										
Tref:	68	°F		Moisture Content:	13.7	%					
Stack Area:	38.84	ft <sup>2</sup>									
METHOD 3A, 6C, 7E DATA											
Analyzer Span	19.15	18.94						5	1.30	1.1402	354
Actual Span Value	10.78	10.56						4	1.10	1.0488	355
Pre Test Zero Direct	0.00	-0.02						3	1.00	1.0000	356
Pre Test Span Direct	10.77	10.18						2	0.98	0.9899	357
Pre-test Zero	0.03	0.08						1	1.00	1.0000	354
Pre-test Span	10.73	10.19						5	1.40	1.1832	356
Average	8.85	11.20						4	1.40	1.1832	355
								3	1.20	1.0954	357
Post Test Zero Direct	-0.01	-0.03						2	1.00	1.0000	354
Post Test Span Direct	10.67	10.42						1	0.98	0.9899	352
Post-test Zero	0.03	0.06						TEST SUMMARY			
Post-test Span	10.64	10.00						O <sub>2</sub> :	8.922	% dry	
Average	8.85	11.20							7.702	% wet	
Corr. Results	8.92	11.72						CO <sub>2</sub> :	11.724	% dry	
Calibration Error	-0.1%	-2.0%							10.121	% wet	
Pre-Test Zero Bias	0.1%	0.5%						H <sub>2</sub> O:	13.7	%	
Pre-Test Span Bias	-0.2%	0.1%						MW:	28.56	lb/lb-mole	
Post-Test Zero Bias	0.2%	0.5%						Flow:	163,734	wacfm	
Post-Test Span Bias	-0.2%	-2.3%							92.71	mdscfm	
Zero Drift	0.0%	-0.1%							5562.34	kdscfh	
Span Drift	-0.4%	-1.1%									

## **Appendix C.2.3**

### **Unit 1 Particulate Calculations**

# EPA METHOD 5 SOURCE TEST

## DATA AND WORKSHEET

Client	Desert View Power	Parameter	Full Load	
Location	Mecca	Fuel	Biomass	
Unit	1	Data By	DW	
Test Number	1-PM-U1	2-PM-U1	3-PM-U1	Average
Reference Temperature, F	68	68	68	
Test Date	3/12/2021	3/12/2021	3/12/2021	
Sample Train	30-WCS	30-WCS	30-WCS	-
Pitot Factor	0.840	0.840	0.840	-
Meter Calibration Factor	0.983	0.983	0.983	-
Stack Area (sq ft)	38.84	38.84	38.84	-
Sample Time (Min)	120	120	120	120
Barometric Pressure (in Hg)	30.22	30.22	30.22	30.22
Nozzle Diam (in)	0.239	0.239	0.239	0.239
Start/Stop Time	840/1100	1120/1336	1352/1602	-
Stack Pressure (iwg)	0.49	0.49	0.50	0.49
Delta P (iwg)	1.002	0.9759	0.9906	0.9894
Meter Pressure (iwg)	1.757	1.753	1.757	1.756
Stack Temperature (F)	363.0	362.9	362.6	362.8
Meter Temperature (F)	69.5	78.9	73.4	73.9
Meter Volume (acf)	89.125	90.560	90.760	90.148
Liquid Volume (ml)	274.0	283.3	315.3	290.9
Stack O2 (%)	9.12	9.31	9.03	9.2
Stack CO2 (%)	11.60	11.38	11.70	11.6
Standard Sample Volume (SCF)	88.594	88.463	89.568	88.875
Moisture Fraction	0.127	0.131	0.142	0.134
Molecular Weight (wet)	28.66	28.59	28.49	28.58
Stack Gas Velocity (ft/sec)	69.91	69.09	69.72	69.57
Stack Flow Rate (wacfm)	162,912	161,000	162,466	162,126
Stack Flow Rate (dscfm)	92,202	90,718	90,405	91,108
Isokinetic Ratio (%)	99.79	101.27	102.89	101.32
<b>Analysis</b>				
Filter mg	0.90	0.50	2.20	1.20
Probe/Nozzle mg	0.30	2.50	2.40	1.73
Particulate Catch, mg	1.20	3.00	4.60	2.93
<b>Particulate Emissions</b>				
Grain Loading gr/dscf	0.00021	0.00052	0.00079	0.00051
Grain Loading @ 12% CO2	0.00022	0.00055	0.00081	0.00053
Part emission lb/hr	0.165	0.407	0.614	0.395
F-Factor (dscf/MMBtu)	9240	9240	9240	
Emission rate, lb/MMBtu	0.0005	0.0012	0.0018	0.0012

**MOBILE EMISSION LABORATORY**  
**CONTINUOUS GASEOUS MEASUREMENTS SUMMARY**

Client: Desert View Power Condition: ----  
 Unit: 1 Load: > 90%  
 Location: Mecca Date 3/12/2021

	O2%	CO2%		
Analyzer Range:	20	20		
Span Value:	10.78	10.56		
	O2%	CO2%		
As Found	10.855	10.434		
Linearity	0.4%	-0.6%		
3/12/2021	O2%	CO2%		
1 -HCL-U1				
Analyzer Range:	20	20		
Span Value:	10.78	10.56		
Pre test Direct Zero	0.00	0.01		
Pre test Direct Span	10.86	10.43		
System Zero	0.00	0.12		
System Span	10.82	10.50		
Average	9.15	11.52		
System Zero	0.00	0.12		
System Span	10.82	10.50		
Post test Direct Zero	-0.01	0.05		
Post test Direct Span	10.85	10.49		
Corrected Conc.	9.12	11.60		
System Bias Check				
Zero Pre-test	0.02%	0.59%		< 5% <b>PASS</b>
Zero Post-test	0.02%	0.59%		< 5% <b>PASS</b>
Span Pre-test	0.20%	-0.29%		< 5% <b>PASS</b>
Span Post-test	0.20%	-0.29%		<5% <b>PASS</b>

3/12/2021		O2%	CO2%		
2-CEM-U1					
Analyzer Range:	20	20			
Span Value:	10.78	10.56			
Pre test Direct Zero	-0.01	0.05			
Pre test Direct Span	10.85	10.49			
System Zero	0.00	0.12			
System Span	10.82	10.50			
Raw concentration	9.34	11.29			
System Zero	0.00	0.12			
System Span	10.81	10.47			
Post test Direct Zero	-0.02	0.05			
Post test Direct Span	10.83	10.46			
Corrected Conc.	9.31	11.38			
System Bias Check					
Zero Pre-test	0.02%	0.59%		< 5%	PASS
Zero Post-test	0.01%	0.58%		< 5%	PASS
Span Pre-test	0.20%	-0.29%		< 5%	PASS
Span Post-test	0.14%	-0.47%		<5%	PASS
3/12/2021		O2%	CO2%		
3-CEM-U1					
Analyzer Range:	20	20			
Span Value:	10.78	10.56			
Pre test Direct Zero	-0.02	0.05			
Pre test Direct Span	10.83	10.46			
System Zero	0.00	0.12			
System Span	10.81	10.47			
Raw concentration	9.06	11.57			
System Zero	0.00	0.13			
System Span	10.80	10.46			
Post test Direct Zero	-0.03	0.04			
Post test Direct Span	10.83	10.43			
Corrected Conc.	9.03	11.70			
System Bias Check					
Zero Pre-test	0.01%	0.58%		< 5%	PASS
Zero Post-test	0.02%	0.65%		< 5%	PASS
Span Pre-test	0.14%	-0.47%		< 5%	PASS
Span Post-test	0.11%	-0.53%		<5%	PASS

1-PM-UI				2-PM-UI				3-PM-UI				
dP	(dP)^.5	dH	Ts	Tm	Ts	(dP)^.5	dH	Ts	Tm	Ts	(dP)^.5	dH
5	1.10	1.049	1.9	364	63	1.049	2.0	363	75	76	1.000	1.8
4	0.98	0.990	1.7	363	64	1.20	1.095	2.1	362	76	1.095	2.1
3	0.87	0.933	1.5	364	63	1.20	1.095	2.1	363	77	1.30	1.140
2	0.99	0.995	1.7	364	65	2	1.10	1.049	2.0	363	79	2
1	1.00	1.000	1.7	365	64	1	1.00	1.000	1.8	362	80	1
2	0.66	0.812	1.1	364	66	2	1.40	1.183	2.5	363	81	2
1	0.62	0.787	1.1	362	67	1	1.10	1.049	2.0	363	82	1
5	0.96	0.980	1.6	363	64	4	1.10	1.049	2.0	364	80	4
3	0.99	0.995	1.7	364	65	3	1.20	1.095	2.1	364	81	3
4	0.91	0.954	1.6	362	67	4	0.89	0.943	1.6	363	82	4
3	0.85	0.922	1.5	362	67	3	0.85	0.922	1.5	364	82	3
2	1.00	1.000	1.7	362	69	2	0.80	0.894	1.4	364	83	2
1	1.10	1.049	1.9	362	69	1	0.80	0.894	1.4	363	83	1
5	0.85	0.922	1.5	362	71	5	0.85	0.922	1.5	362	80	5
4	0.83	0.911	1.5	361	71	4	0.83	0.911	1.5	363	80	4
3	0.92	0.959	1.6	363	72	3	0.92	0.959	1.6	362	80	3
2	0.97	0.985	1.7	364	72	3	0.96	0.980	1.7	364	79	2
1	0.99	0.995	1.7	363	73	1	0.99	0.995	1.8	362	79	1
5	1.10	1.049	1.9	363	73	5	1.20	1.095	2.1	362	79	5
4	1.30	1.140	2.3	364	73	4	0.95	0.975	1.7	363	78	4
3	1.20	1.095	2.1	364	74	3	0.93	0.964	1.7	364	78	3
2	1.20	1.095	2.1	364	75	2	0.62	0.787	1.1	364	78	2
1	1.00	1.000	1.8	363	75	1	0.60	0.775	1.1	364	77	1
5	1.00	1.000	1.8	363	75	5	0.96	0.980	1.7	363	77	5
4	1.30	1.140	2.3	363	75	4	0.91	0.954	1.6	362	77	4
3	1.20	1.095	2.1	362	75	3	0.85	0.922	1.5	362	76	3
2	1.20	1.095	2.1	363	76	2	1.00	1.000	1.8	362	76	2
1	1.00	1.000	1.8	362	76	1	1.10	1.049	2.0	362	76	1
Average				1.0016	1.757	363.0	69.5	Average	0.9759	1.753	362.9	78.9
Delta P (iwg)				Meter Vol	Imp	Meter Vol	Imp	Meter Vol	Imp	Meter Vol	Imp	Average
Meter Pressure (iwg)				1.002	813.500	971.0	725.3	245.7	Delta P (iwg)	0.976	902.950	948.8
Stack Temperature (F)				1.757	902.625	702.5	694.5	8.0	Meter Pressure (iwg)	1.753	993.510	698.6
Meter Temperature (F)				362.967	89.125	644.1	643.5	0.6	Stack Temperature (F)	362.900	90.560	662.4
Meter Volume (acf)				69.533	936.1	916.4	19.7	Meter Temperature (F)	78.850	946.4	924	22.4
Liquid Volume (ml)				89.125	274.0	0.0	Meter Volume (acf)	90.560	Meter Volume (acf)	0.0	Meter Volume (acf)	90.760
Liquid Volume (ml)				936.1	283.3	Liquid Volume (ml)	283.3	Liquid Volume (ml)	283.3	Liquid Volume (ml)	283.3	315.3

## **Appendix C.2.4**

### **Unit 1 Hydrocarbon Calculations**

**SCAQMD 25.3 SOURCE TEST  
DATA AND WORKSHEET**

Client.....	Desert View Power	Parameter.....	>90%
Loaction.....	Mecca	Fuel.....	Biomass/coke
Unit .....	Unit 1	Data By.....	DW
Test Number.....	1A-VOC-U2	1B-VOC-U2	Average
Reference Temperature, F.....	68	68	
Test Date.....	3/10/2021	3/10/2021	
Sample Time (Min).....	~60	~60	~60
Barometric Pressure (in Hg).....	30.11	30.11	30.11
Start/Stop Time.....	1034/1126	1034/1126	
Stack O2 (%).....	8.86	8.86	8.9
Stack CO2 (%).....	11.80	11.80	11.8
Stack H2O (%).....	14.7%	14.7%	14.7%
Stack Flow Rate (wacfm).....	174,864	174,864	174,864
Stack Flow Rate (dscfm).....	95,412	95,412	95,412
<b>Laboraotory Results</b>			
TGNMO ppm.....	4.60	4.60	4.60
TGNMO ppm @ 3% O2.....	6.84	6.84	6.84
TGNMO lb/hr.....	1.09	1.09	1.09

Note: Flow rates from Test      RATA Run 3

Per Method 25.3 when the difference between the paired canisters is >20% the higher of the two results is used.

## **Appendix C.2.5**

### **Unit 1 Mercury Calculations**

**Montrose AQ\$**  
**Run 1 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA							
GENERAL				Impingers				dP		dP <sup>2</sup>	Temp	Velocity			
Test:	1-O2/CO2-U1			#/Matl.	End	Start	Diff.	Point	(in. H <sub>2</sub> O)	(in. H <sub>2</sub> O <sup>2</sup> )	(°F)	(fps)			
Date:	3/11/2021			1/H2O	780.7	686.6	94.1	5	1.00	1.0000	365	70.03			
Start Time:	15:25			2/H2O	769.2	758.4	10.8	4	1.20	1.0954	366	76.76			
Station:	Desert View Power			3/Empty	608.4	598.6	9.8	3	1.30	1.1402	366	79.89			
Unit:	Unit 1			4/S.G.	936.3	910.0	26.3	2	1.30	1.1402	366	79.89			
Test Condition:	Full Load			Rinse	0.0			1	1.00	1.0000	366	70.07			
Performed By:	RD			Total	141.0			5	1.10	1.0488	366	73.49			
PRE-TEST INFORMATION				Dry Gas Meter				4	1.10	1.0488	366	73.49			
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)	3	1.20	1.0954	366	76.76			
Barom. Pressure:	30.14 "Hg			Start	953.800	62	63	2	1.40	1.1832	361	82.65			
Meter No.	23-WCS			Stop	999.872	62	63	1	1.10	1.0488	361	73.27			
Meter Y <sub>d</sub> :	1.0000			Summary				5	1.10	1.0488	367	73.53			
Meter Pressure:	2.0	iwg	Total	46.072	62.4			4	0.93	0.9644	367	67.61			
Pstack:	0.49	iwg	Sample Volume:				3	0.88	0.9381	368	65.81				
Pstack:	30.17	"Hg	H <sub>2</sub> O Volume :				2	0.85	0.9220	368	64.68				
Cp:	0.84		Moisture Content:				1	0.80	0.8944	367	62.71				
Tref:	68	°F	47.131 dscf				5	0.85	0.9220	364	64.52				
Stack Area:	38.84	ft <sup>2</sup>	6.655 scf				4	0.83	0.9110	364	63.76				
METHOD 3A, 6C, 7E DATA															
<u>O<sub>2</sub></u>				<u>CO<sub>2</sub></u>				12.4 %							
Analyzer Span	19.15	18.94					5	1.20	1.0954	363	76.62				
Actual Span Value	10.78	10.56					4	0.95	0.9747	363	68.17				
Pre Test Zero Direct	-0.02	-0.02					3	0.92	0.9592	363	67.08				
Pre Test Span Direct	10.84	10.42					2	0.62	0.7874	364	55.10				
Pre-test Zero	0.01	0.06					1	0.60	0.7746	364	54.21				
Pre-test Span	10.81	10.42					5	0.96	0.9798	365	68.61				
Average	9.62	10.99					4	0.91	0.9539	366	66.84				
Post Test Zero Direct	-0.02	-0.01					3	0.85	0.9220	366	64.60				
Post Test Span Direct	10.84	10.42					2	1.00	1.0000	366	70.07				
Post-test Zero	0.00	0.05					1	1.10	1.0488	366	73.49				
Post-test Span	10.81	10.42					Average				Average 0.9891 0.9945 365.1 69.65				
Average	9.62	10.99					TEST SUMMARY								
Corr. Results	9.59	11.14					O <sub>2</sub> :	9.591 % dry							
Cal Error <2%, Bias <5%; Drift <3%															
Calibration Error	0.3%	-0.8%					8.404 % wet								
Pre-Test Zero Bias	0.1%	0.4%					CO <sub>2</sub> :	11.139 % dry							
Pre-Test Span Bias	-0.1%	0.0%					9.761 % wet								
Post-Test Zero Bias	0.1%	0.3%					H <sub>2</sub> O:	12.4 %							
Post-Test Span Bias	-0.2%	0.0%					MW:	28.66 lb/lb-mole							
Zero Drift	-0.1%	-0.1%					Flow:	162,311 wacfm							
Span Drift	0.0%	0.0%					91.78 mdscfm								
							5506.83 kdscfh								

**Montrose AQS**  
**Run 2 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA							
GENERAL				Impingers											
Test:	2-O2/CO2-U1			#/Matl.	End	Start	Diff.	Point	dP (in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	Temp (°F)	Velocity (fps)			
Date:	3/11/2021			1/H <sub>2</sub> O	859.6	764.6	95.0	5	1.00	1.0000	361	69.91			
Start Time:	16:50			2/H <sub>2</sub> O	759.6	747.9	11.7	4	1.20	1.0954	360	76.54			
Station:	Desert View Power			3/Empty	650.3	642.3	8.0	3	1.20	1.0954	360	76.54			
Unit:	Unit 1			4/S.G.	969.8	939.8	30.0	2	1.00	1.0000	359	69.83			
Test Condition:	Full Load			Rinse		0.0		1	1.00	1.0000	359	69.83			
Performed By:	RD			Total		144.7		5	1.10	1.0488	359	73.24			
PRE-TEST INFORMATION				Dry Gas Meter				4	1.10	1.0488	358	73.19			
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)	3	1.20	1.0954	359	76.49			
Barom. Pressure:	30.14 "Hg			Start	1.000	58	58	2	1.30	1.1402	360	79.67			
						59	59	1	1.20	1.0954	361	76.59			
Meter No.	23-WCS			Stop	45.122	57	58	5	1.00	1.0000	359	69.83			
Meter Y <sub>d</sub> :	1.0000					58	59	4	0.94	0.9695	360	67.74			
Meter Pressure:	2.0 iwg			Total	44.122		58.3	3	0.89	0.9434	361	65.96			
Pstack:	0.49 iwg							2	0.86	0.9274	363	64.92			
Pstack:	30.17 "Hg			Summary				1	0.82	0.9055	363	63.39			
Cp:	0.84			Sample Volume:	45.496	dsfcf		5	0.84	0.9165	361	64.08			
Tref:	68 °F			H <sub>2</sub> O Volume :	6.830	scf		4	0.83	0.9110	361	63.70			
Stack Area:	38.84 ft <sup>2</sup>			Moisture Content:	13.1	%		3	0.94	0.9695	361	67.78			
METHOD 3A, 6C, 7E DATA															
<u>O<sub>2</sub></u>				<u>CO<sub>2</sub></u>											
Analyzer Span	19.15	18.94						5	1.20	1.0954	359	76.49			
Actual Span Value	10.78	10.56						4	0.95	0.9747	358	68.02			
Pre Test Zero Direct	-0.02	-0.01						3	0.93	0.9644	357	67.26			
Pre Test Span Direct	10.84	10.42						2	0.63	0.7937	357	55.36			
Pre-test Zero	0.00	0.05						1	0.60	0.7746	358	54.06			
Pre-test Span	10.81	10.42						5	0.96	0.9798	360	68.46			
Average	9.24	11.32						4	0.91	0.9539	360	66.65			
								3	0.85	0.9220	360	64.42			
Post Test Zero Direct	-0.02	-0.02						2	1.00	1.0000	359	69.83			
Post Test Span Direc	10.84	10.42						1	1.10	1.0488	359	73.24			
Post-test Zero	0.00	0.07						Average	0.9778	0.9888	359.7	69.08			
Post-test Span	10.81	10.43													
Average	9.24	11.32													
Corr. Results	9.22	11.48													
Cal Error <2%, Bias <5%; Drift <3%															
Calibration Error	0.3%	-0.8%													
Pre-Test Zero Bias	0.1%	0.3%													
Pre-Test Span Bias	-0.2%	0.0%													
Post-Test Zero Bias	0.1%	0.4%													
Post-Test Span Bias	-0.1%	0.1%													
Zero Drift	0.0%	0.1%													
Span Drift	0.0%	0.0%													

**Montrose AQs**  
**Run 3 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 1**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA				
				Impingers								
				#/Matl.	End	Start	Diff.	Point	dP	dP <sup>2</sup>	Temp	Velocity
Test:	3-O2/CO2-U1			1/H2O	856.7	758.7	98.0	5	1.10	1.0488	361	73.30
Date:	3/11/2021			2/H2O	765.1	752.4	12.7	4	1.30	1.1402	360	79.64
Start Time:	18:10			3/Empty	641.8	637.8	4.0	3	1.20	1.0954	360	76.51
Station:	Desert View Power			4/S.G.	1000.8	969.8	31.0	2	1.20	1.0954	363	76.65
Unit:	Unit 1			Rinse			0.0	1	1.00	1.0000	363	69.98
Test Condition:	Full Load			Total			145.7	5	1.20	1.0954	363	76.65
Performed By:	RD			Dry Gas Meter				4	1.20	1.0954	363	76.65
PRE-TEST INFORMATION				Time	Vol.	Tm(in)	Tm(out)	3	1.30	1.1402	364	79.83
Barom. Pressure:		psi		Start	45.800	56	57	2	1.40	1.1832	364	82.85
	30.14	"Hg				56	57	1	1.10	1.0488	363	73.39
Meter No.	23-WCS			Stop	89.872	56	57	5	1.10	1.0488	360	73.26
Meter Y <sub>d</sub>	1.0000					57	51	4	0.92	0.9592	361	67.04
Meter Pressure:	2.0	iwg		Total	44.072		55.9	3	0.88	0.9381	360	65.52
Pstack:	0.49	iwg		Summary				2	0.84	0.9165	361	64.06
Pstack:	30.17	"Hg		Sample Volume:	45.653	dsfcf		1	0.79	0.8888	360	62.08
Cp:	0.84			H <sub>2</sub> O Volume :	6.877	scf		5	0.84	0.9165	359	63.98
Tref:	68	°F		Moisture Content:	13.1	%		4	0.82	0.9055	363	63.37
Stack Area:	38.84	ft <sup>2</sup>						3	0.92	0.9592	362	67.08
METHOD 3A, 6C, 7E DATA								2	0.98	0.9899	362	69.23
	O <sub>2</sub>	CO <sub>2</sub>						1	0.98	0.9899	362	69.23
Analyzer Span	19.15	18.94						5	1.20	1.0954	362	76.61
Actual Span Value	10.78	10.56						4	0.95	0.9747	363	68.20
Pre Test Zero Direct	-0.02	-0.02						3	0.93	0.9644	364	67.52
Pre Test Span Direct	10.84	10.42						2	0.62	0.7874	363	55.10
Pre-test Zero	0.00	0.07						1	0.60	0.7746	362	54.17
Pre-test Span	10.81	10.43						5	0.96	0.9798	360	68.44
Average	9.05	11.55						4	0.91	0.9539	361	66.67
								3	0.85	0.9220	362	64.48
Post Test Zero Direct	-0.02	-0.01						2	1.00	1.0000	363	69.98
Post Test Span Direct	10.85	10.42						1	1.10	1.0488	364	73.44
Post-test Zero	0.00	0.05						Average	0.9971	0.9985	361.9	69.83
Post-test Span	10.81	10.42										
Average	9.05	11.55										
Corr. Results	9.02	11.71										
Cal Error <2%, Bias <5%; Drift <3%												
Calibration Error	0.3%	-0.8%										
Pre-Test Zero Bias	0.1%	0.4%										
Pre-Test Span Bias	-0.1%	0.1%										
Post-Test Zero Bias	0.1%	0.3%										
Post-Test Span Bias	-0.2%	0.0%										
Zero Drift	0.0%	-0.1%										
Span Drift	0.0%	-0.1%										

Test Number	Date	QA/QC Spike Pair						QA/QC Spike Pair						Average
		1-Hg-A Point 15:25	1-Hg-B Point 16:25	1-Hg-C Point 15:25	2-Hg-A Point 16:50	2-Hg-B Point 17:50	2-Hg-C Point 16:50	3-Hg-A Point 18:10	3-Hg-B Point 17:50	3-Hg-C Point 18:10	3-Hg-S Point 19:10	QA/QC Spike Pair		
W0024	End time	Total Hg No OLC160589	Total Hg No OLC149182	Total Hg Yes OL544313	Total Hg No OLC160643	Total Hg No OLC160707	Total Hg No OLC160571	Total Hg Yes OLC544358	Total Hg No OLC136861	Total Hg No OLC160585	Total Hg No OLC150653	Total Hg Yes OLC544362		
Test Type	Spiked	Normal	Normal	Normal	Normal	Normal								
Sample ID	Spiked Condition	8.61		9.08		10.26		10.07		13.43		13.04		
Solvent Trap Result	Avg if paired samples, result if single, ug/dsm3													
Sampling Data	Total volume, dsm3	0.04067	0.04106	0.04077	0.04112	0.04109	0.04112	0.04127	0.04104	0.04121	0.04094			
	Total volume, dscf	1.43618	1.43684	1.44970	1.45185	1.45074	1.45179	1.45220	1.44915	1.45517	1.44559			
	Moisture, %, from Flow test	12.373	12.373	12.373	13.053	13.053	13.053	13.092	13.092	13.092	13.092			
Stack CO2, %	9.59	9.59	9.59	9.59	9.22	9.22	9.22	9.02	9.02	9.02	9.02			
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 68°	11.14	11.14	11.14	11.14	11.48	11.48	11.48	11.71	11.71	11.71	11.71			
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 60°	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240			
Flow, dscf	91.780	91.780	91.780	91.780	91.780	91.780	91.780	91.780	91.780	91.780	91.780			
Laboratory Data														
ng, Sec 1	346.60	344.40	381.50	352.10	404.30	435.30	404.60	416.00	550.10	545.00	539.00	527.00		
ng, Sec 2	4.49	5.07	6.05	3.32	2.20	1.28	2.60	0.00	6.10	4.60	4.70	1.00		
ng, Total	351.09	349.47	387.55	355.42	406.50	436.58	407.20	416.00	556.20	549.60	543.70	528.00	400	
Spike Level, ng				400				400						
Spike result ng, Sec 1				752.10				816.00				927.00		
Spike result ng, Sec 2				3.32				0.00				1.00		
Spike result ng, total				755.42				816.00				928.00		
Results														
Total ug/dsm3	8.632	8.588	9.439	8.717	9.886	10.626	9.904	10.227	13.477	13.392	13.193	12.897	10.767	
Total ug/dscf	0.244	0.243	0.267	0.247	0.280	0.301	0.280	0.290	0.382	0.379	0.374	0.365	0.305	
Total lb/hr	2.97E-03	2.96E-03	3.24E-03	2.98E-03	3.36E-03	3.62E-03	3.37E-03	3.48E-03	4.62E-03	4.59E-03	4.52E-03	4.42E-03	3.68E-03	
Total lb/MMBtu	9.19E-06	9.15E-06	1.01E-05	9.29E-06	1.02E-05	1.10E-05	1.05E-05	1.05E-05	1.37E-05	1.36E-05	1.34E-05	1.31E-05	1.11E-05	
QA/QC	Spike, ug/dsm3													
	Spike, expected, ug/dsm3													
	Spike, actual (spike-sample), ug/dsm3													
	% recovery													
Breakthrough, on sample, Sec 2, %	1.3%	1.5%	1.6%	0.9%	0.5%	0.3%	0.6%	0.0%	1.1%	0.8%	0.9%	0.2%	0.3%	
Relative Percent Difference on paired samples														
MACT Limit	Mercury	10.767												
	ug/dscm	3.68E-03												
	lb/hr (as Hg)													
	lb/MMBtu	1.11E-05												
	5.70E-06													

Note: <10% breakthrough is criteria in most cases  
<10% RPD is criteria for paired trains in most cases  
85%-115% average spike recovery is Method 30B criteria  
Low sample levels show more variation

**Mercury by Method 30B**  
**Desert View Power - Unit 1**

Test Number	1-Hg-A	1-Hg-B	2-Hg-A	2-Hg-B	3-Hg-A	3-Hg-B	Averages	Limits
Date	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021		
Start Time	15:25	15:25	16:50	16:50	18:10	18:10		
End Time	16:25	16:25	17:50	17:50	19:10	19:10		
<b>Pre-Test Information:</b>								
Fuel F <sub>d</sub> Factor, dscf/MMBtu	9,240	9,240	9,240	9,240	9,240	9,240		
Reference Temperature, °F	68	68	68	68	68	68		
<b>Pollutant Emissions:</b>								
<b>Mercury</b>								
Total ug/dscm	8.632	8.588	9.886	10.626	13.477	13.392	10.767	
ug/dscf	0.244	0.243	0.280	0.301	0.382	0.379	0.305	
lb/MMBtu	9.19E-06	9.15E-06	1.02E-05	1.10E-05	1.37E-05	1.36E-05	1.11E-05	<b>5.70E-06</b>

Date	Start Time	End Time	Run #	Trap #	Spiked / Unspiked	Start Vol. I	Stop Vol. I	Total Vol. I	Total Vol. m3	Meter No.	Yd	delta H	Meter Temp	Stack Temp	Trap Temp	Ref Temp	Vm std. dscf		
Point 15:25	16:25	16:25	OLC160389	OLC137222	Unspiked	5080.875	5121.100	40.225	0.040225	1.4203	20-A	0.99887	0.00	65.3	301.3	1.0	30.14	0.04067	
Point 15:25	16:25	16:25	OLC149182	OLC544313	Unspiked	9479.109	9519.300	40.191	0.040191	1.4191	21-C	0.99888	0.00	60.0	301.3	1.0	30.14	0.04069	
Point 15:25	16:25	16:25	1-Hg-C	1-Hg-S	Spiked	3181.747	3222.013	40.286	0.040286	1.4218	21-S	0.99010	0.00	60.0	301.3	1.0	30.14	0.04077	
Point 16:50	17:50	17:50	OLC160343	OLC160707	Unspiked	5122.357	5162.492	40.135	0.040135	1.4172	20-A	0.9989	0.00	58.5	359.0	300.0	1.0	30.14	0.04112
Point 16:50	17:50	17:50	OLC160571	OLC544358	Unspiked	9520.726	9560.859	40.133	0.040133	1.4171	21-C	0.9989	0.00	58.5	359.0	300.0	1.0	30.14	0.04112
Point 16:50	17:50	17:50	2-Hg-C	2-Hg-S	Spiked	3223.098	3263.231	40.132	0.040132	1.4171	21-S	0.9901	0.00	58.5	359.0	300.0	1.0	30.14	0.04067
Point 18:10	19:10	19:10	OLC136861	OLC160385	Unspiked	5163.246	5203.329	40.283	0.040233	1.4224	20-A	0.9989	0.00	58.5	362.0	301.0	1.0	30.14	0.04127
Point 18:10	19:10	19:10	OLC160553	OLC544362	Unspiked	9561.274	9601.384	40.110	0.040110	1.4163	21-C	0.9989	0.00	57.0	362.0	301.0	1.0	30.14	0.04121
Point 18:10	19:10	19:10	3-Hg-A	3-Hg-B	Spiked	3263.873	3304.150	40.277	0.040277	1.4222	21-S	0.9901	0.00	58.0	362.0	301.0	1.0	30.14	0.04094

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePres	OfficePres	StackTerm	StackTerm	ProbeTemp	ProbeTemp	TrapTemp	TrapTemp	TrapTemp	PumpVac	PumpVac	Notes
0	10	3:25:00 PM	5080.875	3232.792	n/a	0	0	0	356	336	300	300	300	300	64	1	0.7	
10	20	3:45:00 PM	5082.589	3235.490	n/a	0	0	0	356	336	300	300	300	300	64	1	0.7	
20	30	3:55:00 PM	5094.310	3246.190	n/a	0	0	0	357	337	302	302	302	302	65	1	0.7	
30	40	4:05:00 PM	5101.013	3252.900	n/a	0	0	0	357	337	302	302	302	302	66	1	0.7	
40	50	4:15:00 PM	5107.725	3258.602	n/a	0	0	0	356	336	302	302	302	302	66	1	0.7	
50	60	4:25:00 PM	5111.438	3266.301	n/a	0	0	0	356	336	302	302	302	302	66	1	0.7	
60	70	4:25:00 PM	5121.100	3273.007														

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePres	OfficePres	StackTerm	StackTerm	ProbeTemp	ProbeTemp	TrapTemp	TrapTemp	TrapTemp	PumpVac	PumpVac	Notes
0	10	3:25:00 PM	9479.109	3181.747	n/a	0	0	0	359	339	300	300	300	300	61	1	0.7	
10	20	3:45:00 PM	9481.808	3188.512	n/a	0	0	0	359	339	300	300	300	300	61	1	0.7	
20	30	3:55:00 PM	9492.509	3195.165	n/a	0	0	0	357	337	302	302	302	302	60	1	0.7	
30	40	4:05:00 PM	9493.209	3201.877	n/a	0	0	0	356	336	302	302	302	302	60	1	0.7	
40	50	4:15:00 PM	9505.900	3208.591	n/a	0	0	0	356	336	302	302	302	302	59	1	0.7	
50	60	4:25:00 PM	9512.609	3215.300	n/a	0	0	0	356	336	302	302	302	302	59	1	0.7	
60	70	4:25:00 PM	9518.300	3222.013														

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePres	OfficePres	StackTerm	StackTerm	ProbeTemp	ProbeTemp	TrapTemp	TrapTemp	TrapTemp	PumpVac	PumpVac	Notes
0	10	3:25:00 PM	9479.109	3181.747	n/a	0	0	0	359	339	300	300	300	300	53	1	0.7	
10	20	3:45:00 PM	9481.808	3188.512	n/a	0	0	0	359	339	300	300	300	300	53	1	0.7	
20	30	3:55:00 PM	9492.509	3195.165	n/a	0	0	0	357	337	302	302	302	302	58	1	0.7	
30	40	4:05:00 PM	9493.209	3201.877	n/a	0	0	0	356	336	302	302	302	302	60	1	0.7	
40	50	4:15:00 PM	9505.900	3208.591	n/a	0	0	0	356	336	302	302	302	302	59	1	0.7	
50	60	4:25:00 PM	9512.609	3215.300	n/a	0	0	0	356	336	302	302	302	302	60	1	0.7	
60	70	4:25:00 PM	9518.300	3222.013														

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePres	OfficePres	StackTerm	StackTerm	ProbeTemp	ProbeTemp	TrapTemp	TrapTemp	TrapTemp	PumpVac	PumpVac	Notes
0	10	4:50:00 PM	9520.726	3223.099	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
10	20	5:00:00 PM	9521.410	3229.747	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
20	30	5:10:00 PM	9523.114	3236.415	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
30	40	5:20:00 PM	9540.792	3243.165	n/a	0	0	0	359	339	300	300	300	300	58	1	0.7	
40	50	5:30:00 PM	9541.428	3249.615	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
50	60	5:40:00 PM	9541.110	3201.366	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
60	70	5:50:00 PM	9542.492	3249.844	n/a	0	0	0	359	339	300	300	300	300	58	1	0.7	
70	80	6:00:00 PM	9543.177	3256.443	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePres	OfficePres	StackTerm	StackTerm	ProbeTemp	ProbeTemp	TrapTemp	TrapTemp	TrapTemp	PumpVac	PumpVac	Notes
0	10	4:50:00 PM	9520.726	3223.099	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
10	20	5:00:00 PM	9521.410	3229.747	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
20	30	5:10:00 PM	9523.114	3236.415	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
30	40	5:20:00 PM	9540.792	3243.165	n/a	0	0	0	359	339	300	300	300	300	58	1	0.7	
40	50	5:30:00 PM	9541.428	3249.615	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
50	60	5:40:00 PM	9541.110	3201.366	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
60	70	5:50:00 PM	9542.492	3249.844	n/a	0	0	0	359	339	300	300	300	300	58	1	0.7	
70	80	6:00:00 PM	9543.177	3256.443	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePres	OfficePres	StackTerm	StackTerm	ProbeTemp	ProbeTemp	TrapTemp	TrapTemp	TrapTemp	PumpVac	PumpVac	Notes
0	10	4:50:00 PM	9520.726	3223.099	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
10	20	5:00:00 PM	9521.410	3229.747	n/a	0	0	0	359	339	300	300	300	300	59	1	0.7	
20	30	5:10:00 PM	9523.114	3236.415	n/a	0	0	0	359	339	300							

Run: 3-Hg-A									
Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OrificePres	OrificePres	StackT <sub>e</sub>
							Actual A	Actual B	mpB
0	0	10	6:10:00 PM	5163.246	3317.735	n/a	0	0	362
10	10	20	6:20:00 PM	5169.861	3324.420	n/a	0	0	362
20	20	30	6:30:00 PM	5176.675	3331.959	n/a	0	0	362
30	30	40	6:40:00 PM	5183.387	3337.800	n/a	0	0	362
40	40	50	6:50:00 PM	5190.100	3344.423	n/a	0	0	362
50	50	60	7:00:00 PM	5196.870	3351.170	n/a	0	0	362
60	60	70	7:10:00 PM	5203.529	3357.857	n/a	0	0	362

Run: 3-Hg-B									
Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OrificePres	OrificePres	StackT <sub>e</sub>
							Actual A	Actual B	mpB
0	0	10	6:10:00 PM	5163.246	3317.735	n/a	0	0	362
10	10	20	6:20:00 PM	5169.861	3324.420	n/a	0	0	362
20	20	30	6:30:00 PM	5176.675	3331.959	n/a	0	0	362
30	30	40	6:40:00 PM	5183.387	3337.800	n/a	0	0	362
40	40	50	6:50:00 PM	5190.100	3344.423	n/a	0	0	362
50	50	60	7:00:00 PM	5196.870	3351.170	n/a	0	0	362
60	60	70	7:10:00 PM	5203.529	3357.857	n/a	0	0	362

  

Run: 3-Hg-C									
Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OrificePres	OrificePres	StackT <sub>e</sub>
							Actual D	Actual C	mpB
0	0	10	6:10:00 PM	9561.274	3263.873	n/a	0	0	362
10	10	20	6:20:00 PM	9567.598	3270.880	n/a	0	0	362
20	20	30	6:30:00 PM	9574.544	3277.291	n/a	0	0	362
30	30	40	6:40:00 PM	9581.330	3284.009	n/a	0	0	362
40	40	50	6:50:00 PM	9586.014	3290.120	n/a	0	0	362
50	50	60	7:00:00 PM	9584.689	3297.450	n/a	0	0	362
60	60	70	7:10:00 PM	9601.384	3304.150	n/a	0	0	362

  

Run: 3-Hg-S									
Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OrificePres	OrificePres	StackT <sub>e</sub>
							Actual D	Actual C	mpB
0	0	10	6:10:00 PM	9561.274	3263.873	n/a	0	0	362
10	10	20	6:20:00 PM	9567.598	3270.880	n/a	0	0	362
20	20	30	6:30:00 PM	9574.544	3277.291	n/a	0	0	362
30	30	40	6:40:00 PM	9581.330	3284.009	n/a	0	0	362
40	40	50	6:50:00 PM	9586.014	3290.120	n/a	0	0	362
50	50	60	7:00:00 PM	9584.689	3297.450	n/a	0	0	362
60	60	70	7:10:00 PM	9601.384	3304.150	n/a	0	0	362

## **Appendix C.3 Unit 2 Calculations**

## **Appendix C.3.1 Unit 2 Gaseous Calculations**

**MONTROSE AQ'S**  
**RELATIVE ACCURACY TEST AUDIT**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 2**

PRE-TEST INFORMATION		METHOD 4 DATA			METHOD 2 DATA				
GENERAL		Impingers			Point	dP (in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	Temp (°F)	Velocity (fps)
Test:	1-RA-U2	#/Matl.	End	Start	Diff.				
Date:	3/8/2021	1/H <sub>2</sub> O	917.7	732.8	184.9	5	1.00	328	68.62
Start Time:	8:20	2/H <sub>2</sub> O	712.5	710.6	1.9	4	0.97	330	67.67
Station:	Desert View Power	3/Empty	638.9	638.6	0.3	3	0.95	331	67.01
Unit:	Unit 2	4/S.G.	917.1	905.2	11.9	2	0.82	332	62.30
Test Condition:	Full Load	Rinse		50.0	-50.0	1	0.77	330	60.29
Performed By:	RD	Total			149.0				
PRE-TEST INFORMATION		Dry Gas Meter							
SAMPLE TRAIN		Time	Vol.	Tm(in)	Tm(out)				
Barom. Pressure:	30.14 "Hg	Start	450.500	74	75				
				73	75				
Meter No.	23-WCS	Stop	492.982	78	80				
Meter Y <sub>d</sub> :	1.0000	Total	42.482		75.8				
Meter Pressure:	1.5 iwg	Summary							
Pstack:	0.55 iwg	Sample Volume:	42.316	dscf					
Pstack:	30.18 "Hg	H <sub>2</sub> O Volume :	7.033	scf					
Cp:	0.84	Moisture Content:	14.3	%					
Tref:	68 °F								
Stack Area:	38.84 ft <sup>2</sup>								
METHOD 3A, 6C, 7E DATA									
	O <sub>2</sub>	CO <sub>2</sub>	NO <sub>x</sub>	CO					
Analyzer Span	19.15	18.94	87.00	9.64					
Actual Span Value	10.78	10.56	41.3	4.6					
Pre Test Zero Direct	0.00	0.00	0.01	0.00					
Pre Test Span Direct	10.86	10.41	41.56	4.60					
Pre-test Zero	0.01	0.11	0.25	0.10					
Pre-test Span	10.83	10.41	41.22	4.58					
0-60 min	8.89	11.63	38.26	0.22					
Post Test Zero Direct	-0.01	0.00	0.01	-0.02					
Post Test Span Direct	10.82	10.38	41.33	4.52					
Post-test Zero	0.01	0.13	0.06	0.09					
Post-test Span	10.80	10.37	41.10	4.52					
Average	8.89	11.63	38.26	0.22					
Corr. Results	8.86	11.83	38.39	0.13					
Cal Error <2%, Bias <5%; Drift <3%									
Calibration Error	0.4%	-0.8%	0.3%	0.0%					
Pre-Test Zero Bias	0.1%	0.6%	0.3%	1.0%					
Pre-Test Span Bias	-0.2%	0.0%	-0.4%	-0.3%					
Post-Test Zero Bias	0.1%	0.7%	0.1%	1.2%					
Post-Test Span Bias	-0.1%	0.0%	-0.3%	0.0%					
Zero Drift	0.0%	0.1%	-0.2%	-0.1%					
Span Drift	-0.2%	-0.2%	-0.1%	-0.5%					
CAL STATISTICS		PASS	PASS	PASS	PASS				
RELATIVE ACCURACY DATA									
Parameter	Units	Ref. Meth	CEMS	Diff.	Diff. %				
Flow	kdscfh	5648.30	5229.95	418.35	7.4%				
O <sub>2</sub>	% dry	8.86	8.9	0.00	0.0%				
CO <sub>2</sub>	% dry	11.83	11.6	0.20	1.7%				
NO <sub>x</sub>	ppm dry	38.39	40.1	-1.68	-4.4%				
NO <sub>x</sub>	ppm @ 3% O <sub>2</sub>	57.06	59.6	-2.49	-4.4%				
						0.052	lb/hr		
NO <sub>x</sub>	lb/hr	25.89	25.04	0.85	3.3%				
SO <sub>2</sub>	ppm dry	8.66	9.72	-1.05	-12.2%				
SO <sub>2</sub>	ppm @ 3% O <sub>2</sub>	12.88	14.36	-1.48	-11.5%				
SO <sub>2</sub>	lb/hr	8.13	8.486	-0.358	-4.4%				
CO	ppm dry	0.13	0.00	0.13					
CO	ppm @ 3% O <sub>2</sub>	0.19	0.00	0.19					
CO	lb/hr	0.052	0.000						
TEST SUMMARY									
O <sub>2</sub> :		8.859	% dry						
CO <sub>2</sub> :		11.834	% dry						
NO <sub>x</sub> :		38.386	ppm dry						
		25.885	lb/hr						
SO <sub>2</sub> :		8.6636472	ppm dry						
SO <sub>2</sub> :		8.128	lb/hr						
CO:		0.13	ppm dry						
		0.052	lb/hr						
H <sub>2</sub> O:		14.3	%						
MW:		28.50	lb/lb-mole						
Flow:		163,079	wacfpm						
		94.14	mdscfm						
		5648.30	kdscfh						
SOx Titration Summary									
N BaCl <sub>2</sub>		0.0096899							
Total VOL (ml)		459.4							
Aliquot VOL (ml)		20							
Titrant VOL (ml)		3.88							

**MONTROSE AQ'S**  
**RELATIVE ACCURACY TEST AUDIT**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 2**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA			
GENERAL				Impingers			Point	dP (in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	Temp (°F)	Velocity (fps)
Test:	2-RA-U2	#/Matl.		End	Start	Diff.	5	1.00	1.0000	333	68.81
Date:	3/8/2021	1/H <sub>2</sub> O	804.9	635.7	169.2		4	0.98	0.9899	334	68.16
Start Time:	9:35	2/H <sub>2</sub> O	747.1	742.3	4.8		3	0.94	0.9695	335	66.79
Station:	Desert View Power	3/Empty	595.0	592.0	3.0		2	0.83	0.9110	336	62.80
Unit:	Unit 2	4/S.G.	859.0	839.6	19.4		1	0.76	0.8718	333	59.98
Test Condition:	Full Load	Rinse		50.0	-50.0		5	0.97	0.9849	334	67.81
Performed By:	RD	Total					4	0.95	0.9747	335	67.15
PRE-TEST INFORMATION				Dry Gas Meter			3	0.85	0.9220	336	63.56
SAMPLE TRAIN				Time	Vol.	Tm(in)	2	0.82	0.9055	334	62.35
Barom. Pressure:	30.14 "Hg	Start	494.000	83	85		1	0.78	0.8832	332	60.73
Meter No.	23-WCS				85	88	5	0.86	0.9274	332	63.77
Meter Y <sub>d</sub> :	1.0000	Stop	537.198	86	87		4	0.88	0.9381	332	64.50
Meter Pressure:	1.5 iwg	Total	43.198		85.7		3	0.94	0.9695	333	66.71
Pstack:	0.55 iwg						2	0.92	0.9592	334	66.04
Pstack:	30.18 "Hg	Sample Volume:	42.254	dscf			1	0.98	0.9899	333	68.11
Cp:	0.84	H <sub>2</sub> O Volume :	6.910	scf			5	1.00	1.0000	332	68.76
Tref:	68 °F	Moisture Content:	14.1	%			4	1.10	1.0488	334	72.21
Stack Area:	38.84 ft <sup>2</sup>						3	1.30	1.1402	333	78.45
METHOD 3A, 6C, 7E DATA							2	1.00	1.0000	333	68.81
	O <sub>2</sub>	CO <sub>2</sub>	NO <sub>x</sub>	CO			1	0.96	0.9798	331	67.33
Analyzer Span	19.15	18.94	87.00	9.64			5	1.40	1.1832	332	81.36
Actual Span Value	10.78	10.56	41.3	4.6			4	1.20	1.0954	333	75.37
Pre Test Zero Direct	-0.01	0.00	0.01	-0.02			3	1.30	1.1402	334	78.50
Pre Test Span Direct	10.82	10.38	41.33	4.52			2	1.20	1.0954	332	75.33
Pre-test Zero	0.01	0.13	0.06	0.09			1	1.00	1.0000	333	68.81
Pre-test Span	10.80	10.37	41.10	4.52			5	1.40	1.1832	331	81.31
0-60 min	8.83	11.68	38.88	0.22			4	1.40	1.1832	332	81.36
Post Test Zero Direct	-0.01	0.07	0.02	0.11			3	1.30	1.1402	334	78.50
Post Test Span Direct	10.82	10.48	41.16	4.54			2	0.98	0.9899	331	68.03
Post-test Zero	0.01	0.13	0.07	0.08			1	0.97	0.9849	333	67.77
Post-test Span	10.80	10.44	40.96	4.52		Average	1.0242	1.0120	333.1	69.64	
Average	8.83	11.68	38.88	0.22							
Corr. Results	8.82	11.87	39.14	0.14							
Cal Error <2%, Bias <5%; Drift <3%											
Calibration Error	0.2%	-1.0%	0.0%	-0.8%							
Pre-Test Zero Bias	0.1%	0.7%	0.1%	1.2%							
Pre-Test Span Bias	-0.1%	0.0%	-0.3%	0.0%							
Post-Test Zero Bias	0.1%	0.3%	0.1%	-0.3%							
Post-Test Span Bias	-0.1%	-0.3%	-0.2%	-0.2%							
Zero Drift	0.0%	0.0%	0.0%	-0.1%							
Span Drift	0.0%	0.4%	-0.2%	-0.1%							
CAL STATUS	PASS	PASS	PASS	PASS							
RELATIVE ACCURACY DATA											
Parameter	Units	Ref. Meth	CEMS		Diff.	Diff. %					
Flow	kdscfh	5619.04	5130.45		488.59	8.7%					
O <sub>2</sub>	% dry	8.82	8.9		-0.13	-1.5%					
CO <sub>2</sub>	% dry	11.87	11.8		0.07	0.6%					
NO <sub>x</sub>	ppm dry	39.14	40.6		-1.48	-3.8%					
NO <sub>x</sub>	ppm @ 3% O <sub>2</sub>	57.97	60.8		-2.84	-4.9%					
NO <sub>x</sub>	lb/hr	26.25	24.9		1.35	5.1%					
SO <sub>2</sub>	ppm dry	8.59	9.27		-0.67	-7.8%					
SO <sub>2</sub>	ppm @ 3% O <sub>2</sub>	12.73	13.83		-1.10	-8.6%					
SO <sub>2</sub>	lb/hr	8.020	7.933		0.087	1.1%					
CO	ppm dry	0.14	0.11		0.03						
CO	ppm @ 3% O <sub>2</sub>	0.20	0.16		0.04						
CO	lb/hr	0.057	0.041								
TEST SUMMARY											
O <sub>2</sub> :		8.816	% dry								
CO <sub>2</sub> :		11.873	% dry								
NO <sub>x</sub> :		39.136	ppm dry								
H <sub>2</sub> O:		26.254	lb/hr								
SO <sub>2</sub> :		8.592399	ppm dry								
N BaCl <sub>2</sub>		0.0096899									
Total VOL (ml)		422.3									
Aliquot VOL (ml)		20									
Titrant VOL (ml)		4.18									
SOx Titration Summary											
B1/2											

**MONTROSE AQ'S**  
**RELATIVE ACCURACY TEST AUDIT**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 2**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA			
GENERAL				Impingers			Point	dP (in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	Temp (°F)	Velocity (fps)
Test:	3-RA-U2	#/Matl.	End	Start	Diff.		5	0.97	0.9849	330	67.55
Date:	3/8/2021	1/H2O	905.6	731.7	173.9		4	0.96	0.9798	331	67.25
Start Time:	10:52	2/H2O	724.9	719.8	5.1		3	0.92	0.9592	332	65.87
Station:	Desert View Power	3/Empty	640.0	638.9	1.1		2	0.81	0.9000	331	61.77
Unit:	Unit 2	4/S.G.	925.6	917.1	8.5		1	0.75	0.8660	331	59.44
Test Condition:	Full Load	Rinse		50.0	-50.0						
Performed By:	RD	Total			138.6						
PRE-TEST INFORMATION				Dry Gas Meter							
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)				
Barom. Pressure:	30.14	psi	Start	538.500	84	85					
	"Hg				85	90					
Meter No.	23-WCS		Stop	581.334	87	90					
Meter Y <sub>d</sub> :	1.0000										
Meter Pressure:	1.5	iwg									
Pstack:	0.55	iwg	Total	42.834		86.8					
Pstack:	30.18	"Hg									
Cp:	0.84										
Tref:	68	°F									
Stack Area:	38.84	ft <sup>2</sup>									
METHOD 3A, 6C, 7E DATA											
	O <sub>2</sub>	CO <sub>2</sub>	NO <sub>x</sub>	CO							
Span	19.15	18.94	87.00	9.64							
Actual Span Value	10.78	10.56	41.3	4.6							
Pre Test Zero Direct	-0.01	0.07	0.02	0.11							
Pre Test Span Direct	10.82	10.48	41.16	4.54							
Pre-test Zero	0.01	0.13	0.07	0.08							
Pre-test Span	10.80	10.44	40.96	4.52							
0-60 min	8.84	11.76	39.13	0.20							
Post Test Zero Direct	-0.01	0.01	0.02	-0.02							
Post Test Span Direct	10.83	10.43	41.21	4.54							
Post-test Zero	0.01	0.09	0.06	0.08							
Post-test Span	10.80	10.45	40.75	4.52							
Average	8.84	11.76	39.13	0.20							
Corr. Results	8.82	11.91	39.56	0.13							
Cal Error <2%, Bias <5%; Drift <3%											
Calibration Error	0.2%	-0.4%	-0.2%	-0.6%							
Pre-Test Zero Bias	0.1%	0.3%	0.1%	-0.3%							
Pre-Test Span Bias	-0.1%	-0.3%	-0.2%	-0.2%							
Post-Test Zero Bias	0.1%	0.4%	0.1%	1.0%							
Post-Test Span Bias	-0.1%	0.1%	-0.5%	-0.2%							
Zero Drift	0.0%	-0.2%	0.0%	0.0%							
Span Drift	0.0%	0.1%	-0.2%	0.0%							
GAL STATUS	PASS	PASS	PASS	PASS							
RELATIVE ACCURACY DATA											
Parameter	Units	Ref. Meth	CEMS	Diff.	Diff. %						
Flow	kdscfh	5604.05	5085.67	518.39	9.3%						
O <sub>2</sub>	% dry	8.82	8.9	-0.12	-1.4%						
CO <sub>2</sub>	% dry	11.91	11.8	0.11	1.0%						
NO <sub>x</sub>	ppm dry	39.56	40.9	-1.31	-3.3%						
NO <sub>x</sub>	ppm @ 3% O <sub>2</sub>	58.61	61.1	-2.51	-4.3%						
						0.053	lb/hr				
NO <sub>x</sub>	lb/hr	26.47	24.8648	1.60	6.0%	H <sub>2</sub> O:	13.5	%			
SO <sub>2</sub>	ppm dry	8.92	10.35	-1.43	-16.0%	MW:	28.60	lb/lb-mole			
SO <sub>2</sub>	ppm @ 3% O <sub>2</sub>	13.21	15.36	-2.15	-16.3%	Flow:	160,567	wacfm			
						93.40	mdscfm				
						5604.05	kdscfh				
						SOx Titration Summary					
SO <sub>2</sub>	lb/hr	8.302	8.810	-0.507	-6.1%						
CO	ppm dry	0.13	0.58	-0.45		B1/2					
CO	ppm @ 3% O <sub>2</sub>	0.19	0.86	-0.67		N BaCl <sub>2</sub>	0.0096899				
						Total VOL (ml)	428.6				
						Aliquot VOL (ml)	20				
						Titrant VOL (ml)	4.23				
CO	lb/hr	0.053	0.214	-0.16							

## **Appendix C.3.2**

### **Unit 2 Hydrogen Chloride Calculations**

## Desert View Power - Unit 2

Test No	1-HCl	2-HCl	3-HCl	Average	Limit
Date	3/4/2021	3/4/2021	3/4/2021		
Start Time	7:25	9:55	12:25		
Stop Time	9:25	11:55	14:25		

---

### Test Information

---

Reference Temperature, °F	68	68	68
---------------------------	----	----	----

---

### Diluent Emissions and Stack Flow Rate

---

Moisture Fraction, %	13.10	13.28	12.91	13.1
O <sub>2</sub> , % vol. dry	8.62	8.70	8.69	8.67
CO <sub>2</sub> , % vol. Dry	12.09	12.01	11.97	12.02
Stack Flow Rate (dscfm)	92,651	91,402	92,004	91,703
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 68°.....	9,240	9,240	9,240	9,240
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 60°.....	9,100	9,100	9,100	9,100

---

### HCl Emissions

---

ppmvw	6.88	11.50	10.81	9.73	
ppmvd	7.92	13.26	12.41	11.20	
lb/hr (as HCl)	4.2	7.0	6.6	6.79	
lb/MMBtu	<b>0.0118</b>	<b>0.0199</b>	<b>0.0186</b>	<b>0.017</b>	<b>0.022</b>

---

NOTE: O<sub>2</sub>/CO<sub>2</sub> and stack flow are from PM Test.

## **Appendix C.3.3 Unit 2 Particulate Calculations**

## EPA METHOD 5 SOURCE TEST

### DATA AND WORKSHEET

Client	Desert View Power	Parameter	Full Load	
Location	Mecca	Fuel	Biomass	
Unit	Unit 2	Data By	DW	
Test Number	1-PM-U2	2-PM-U2	3-PM-U2	Average
Reference Temperature, F	68	68	68	
Test Date	3/4/2021	3/4/2021	3/28/2018	
Sample Train	23-WCS	23-WCS	23-WCS	-
Pitot Factor	0.840	0.840	0.840	-
Meter Calibration Factor	1.000	1.000	1.000	-
Stack Area (sq ft)	38.84	38.84	38.84	-
Sample Time (Min)	120	120	120	120
Barometric Pressure (in Hg)	30.26	30.26	30.26	30.26
Nozzle Diam (in)	0.239	0.239	0.239	0.239
Start/Stop Time	725/935	955/1200	1225/1430	-
Stack Pressure (iwg)	0.69	0.69	0.69	0.69
Delta P (iwg)	1.009	0.9807	0.9883	0.9925
Meter Pressure (iwg)	1.550	1.633	1.677	1.620
Stack Temperature (F)	355.2	351.9	353.4	353.5
Meter Temperature (F)	59.4	79.8	85.1	74.7
Meter Volume (acf)	85.013	90.252	91.154	88.806
Liquid Volume (ml)	280.3	290.7	281.5	284.2
Stack O2 (%)	8.62	8.70	8.69	8.7
Stack CO2 (%)	12.09	12.01	11.97	12.0
Standard Sample Volume (SCF)	87.725	89.624	89.649	88.999
Moisture Fraction	0.131	0.133	0.129	0.131
Molecular Weight (wet)	28.67	28.64	28.68	28.66
Stack Gas Velocity (ft/sec)	69.75	68.67	68.95	69.12
Stack Flow Rate (wacfm)	162,543	160,033	160,687	161,088
Stack Flow Rate (dscfm)	92,651	91,402	92,004	92,019
Isokinetic Ratio (%)	98.33	101.83	101.20	100.45
<b>Analysis</b>				
Filter mg	0.00	0.00	0.00	0.00
Probe/Nozzle mg	0.00	2.60	4.30	2.30
Particulate Catch, mg	0.00	2.60	4.30	2.30
<b>Particulate Emissions</b>				
Grain Loading gr/dscf	0.00000	0.00045	0.00074	0.0004
Grain Loading @ 12% CO2	0.00000	0.00045	0.00074	0.0004
Part emission lb/hr	0.000	0.351	0.584	0.311
F-Factor (dscf/MMBtu)	9240	9240	9240	
Emission rate, lb/MMBtu	0.0000	0.0010	0.0017	0.0009

MOBILE EMISSION LABORATORY CONTINUOUS GASEOUS MEASUREMENTS SUMMARY					
Client:	Desert View Power	Condition:	----		
Unit:	Unit 2	Load:	> 90%		
Location:	Mecca	Date	3/4/2021		
Analyzer Range:		O2%	CO2%		
Span Value:		20 10.78	20 10.56		
As Found Linearity	O2%	CO2%			
	10.826 0.2%	10.558 0.0%			<2% Pass
3/4/2021	O2%	CO2%			
1pm-cem-U2					
Analyzer Range:	20	20			
Span Value:	10.78	10.56			
Pre test Direct Zero	-0.01	0.00			
Pre test Direct Span	10.83	10.56			
System Zero	0.02	0.07			
System Span	10.82	10.58			
Average	8.64	12.01			
System Zero	-0.02	0.02			
System Span	10.79	10.42			
Post test Direct Zero	0.00	0.09			
Post test Direct Span	10.76	10.44			
Corrected Conc.	8.62	12.09			
System Bias Check					
Zero Pre-test	0.08%	0.33%			< 5% PASS
Zero Post-test	-0.10%	0.10%			< 5% PASS
Span Pre-test	0.19%	0.07%			< 5% PASS
Span Post-test	0.06%	-0.69%			<5% PASS
3/4/2021	O2%	CO2%			
2-CEM-U2					
Analyzer Range:	20	20			
Span Value:	10.78	10.56			
Pre test Direct Zero	-0.02	0.02			
Pre test Direct Span	10.79	10.42			
System Zero	0.00	0.09			
System Span	10.76	10.44			
Raw concentration	8.67	11.76			
Raw concentration	8.67	11.76			
System Zero	-0.03	0.01			
System Span	10.74	10.25			
Post test Direct Zero	-0.01	0.09			
Post test Direct Span	10.72	10.27			
Corrected Conc.	8.70	12.01			
System Bias Check					
Zero Pre-test	-0.01%	0.45%			< 5% PASS
Zero Post-test	-0.13%	0.06%			< 5% PASS
Span Pre-test	-0.09%	-0.61%			< 5% PASS
Span Post-test	-0.18%	-1.53%			<5% PASS

3/10/2015	O2%	CO2%		
3-CEM-U2	20	20		
Analyzer Range:				
Span Value:	10.78	10.56		
Pre test Direct Zero	-0.03	0.01		
Pre test Direct Span	10.74	10.25		
System Zero	-0.01	0.09		
System Span	10.72	10.27		
Raw concentration	8.64	11.64		
System Zero	-0.03	0.06		
System Span	10.73	10.29		
Post test Direct Zero	-0.01	0.15		
Post test Direct Span	10.70	10.28		
Corrected Conc.	8.69	11.97		
System Bias Check				
Zero Pre-test	-0.04%	0.44%	< 5%	PASS
Zero Post-test	-0.13%	0.32%	< 5%	PASS
Span Pre-test	-0.30%	-1.46%	< 5%	PASS
Span Post-test	-0.27%	-1.36%	<5%	PASS



## **Appendix C.3.4**

### **Unit 2 Hydrocarbon Calculations**

**SCAQMD 25.3 SOURCE TEST  
DATA AND WORKSHEET**

Client.....	Desert View Power	Parameter.....	>90%
Location.....	Mecca	Fuel.....	Biomass/coke
Unit .....	Unit 2	Data By.....	DW
Test Number.....	1A-VOC-U2	1B-VOC-U2	Average
Reference Temperature, F.....	68	68	
Test Date.....	3/8/2021	3/8/2021	
Sample Time (Min).....	~60	~60	~60
Barometric Pressure (in Hg).....	30.14	30.14	30.14
Start/Stop Time.....	935/1035	935/1035	
Stack O2 (%).....	8.82	8.82	8.8
Stack CO2 (%).....	11.87	11.87	11.9
Stack H2O (%).....	14.1%	14.1%	14.1%
Stack Flow Rate (wacfm).....	162,287	162,287	162,287
Stack Flow Rate (dscfm).....	93,651	93,651	93,651
<b>Laboratory Results</b>			
TGNMO ppm.....	4.79	2.63	4.79
TGNMO ppm @ 3% O2.....	7.10	3.90	7.10
TGNMO lb/hr.....	1.12	0.61	1.12

Note: Flow rates from Test RATA Run 2

Per Method 25.3 when the difference between the paired canisters is >20% the higher of the two results is used.

## **Appendix C.3.5 Unit 2 Mercury Calculations**

Mercury by Method 30B  
Desert View Power - Unit 2

Test Number	Date	QA/QC Spike Pair											
		1-Hg-A	1-Hg-B	1-Hg-C	2-Hg-S	2-Hg-A	2-Hg-B	3/Hg-C	2-Hg-S	3-Hg-A	3/Hg-B	3-Hg-C	3-Hg-S
10002	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021	3/11/2021
Sink Time	10:20	10:20	10:20	10:20	11:20	11:20	11:20	11:40	11:40	13:15	13:15	13:15	13:15
End Time	11:20	11:20	11:20	11:20				12:40	12:40	14:15	14:15	14:15	14:15
Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg	Total Hg
No	No	No	Yes	No	No	No	No	No	No	No	No	No	Yes
OLC137227	OLC160774	OLC160581	OLC132337	OLC149000	OLC148860	OLC149014	OLC131609	OLC160618	OLC137166	OLC160765	OLC131647		
Normal	Normal	Normal	Normal	Normal	Normal	Normal	Normal	Normal	Normal	Normal	Normal	Normal	Normal
<b>Operating Condition</b>													
<b>Start Trap Result</b>													
Average if paired samples, result if single, ug/dsm3													
Sample 1	38.80	38.80			12.37		11.53		7.78		7.78		8.50
Sampling Data													
Total volume, dsm3	0.04025	0.03981	0.04032	0.04047	0.04024	0.03975	0.04010	0.04109	0.04030	0.03971	0.04005	0.04031	
Total volume, dsm3	1.42113	1.40574	1.42379	1.42890	1.42087	1.40353	1.41599	1.45086	1.42294	1.40211	1.41422	1.42334	
Moisture, from Flow test (Data from HCl)	0.127	0.127	0.127	0.127	0.127	0.127	0.140	0.140	0.140	0.119	0.119	0.119	
Stack O2, %	9.66	9.66	9.66	9.66	9.66	9.66	9.62	9.62	9.62	9.72	9.72	9.72	
Stack CO2, %	11.09	11.09	11.09	11.09	11.09	11.09	11.08	11.08	11.08	11.01	11.01	11.01	
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 68°	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	9.240	
Fuel F <sub>d</sub> Factor, dscf/MMBtu @ 60°	9.100	9.100	9.100	9.100	9.100	9.100	9.100	9.100	9.100	9.100	9.100	9.100	
Flow, dscfm (Data from HCl)	87.469	87.469	87.469	87.469	87.469	87.469	89.454	89.454	89.454	88.235	88.235	88.235	
Laboratory Data													
550c-1	1596.00	1496.00	1542.00	1566.00	540.00	440.00	423.40	504.00	340.00	278.00	315.50	360.30	
550c-2	3.65	11.21	13.82	13.03	7.18	3.24	3.20	6.32	1.20	3.90	5.70	2.00	
Original	1599.65	1507.21	1555.82	1579.03	547.18	443.24	426.60	510.32	341.20	281.90	321.20	362.30	
Spike level, ng					400			400			400		
Spike result ng, Sec 1					1986.00			904.00			760.30		
Spike result ng, Sec 2					13.03			6.32			2.00		
Spike result ng, total					1979.03			910.32			762.30		
Results													
Total ug/dscm	39.746	37.859	38.584	39.020	13.598	11.151	10.638	12.420	8.467	7.099	8.020	8.988	19.653
Total ug/dscf	1.126	1.072	1.093	1.105	0.385	0.316	0.301	0.352	0.240	0.201	0.227	0.256	0.557
Total lb/hr	1.30E-02	1.24E-02	1.26E-02	1.28E-02	4.55E-03	3.73E-03	3.56E-03	4.15E-03	2.80E-03	2.34E-03	2.65E-03	2.97E-03	6.47E-03
Total lb/MMBtu	4.26E-05	4.06E-05	4.14E-05	4.18E-05	1.45E-05	1.19E-05	1.14E-05	1.33E-05	9.12E-06	7.65E-06	8.64E-06	9.68E-06	2.11E-05
QA/QC													
Spike ug/dsm3													
Spike expected ug/dsm3													
Spike, actual (spike-sample), ug/dsm3													
% recovery													
Breakthrough on sample, Sec 2, %	0.2%	0.7%	0.9%	0.8%	1.3%	0.7%	0.8%	1.3%	0.4%	1.4%	1.8%	0.6%	
Relative Percent Difference on paired samples													
	2.4%				0.6%			4.5%			3.0%		6.1%
Mercury													
ug/dscm													
lb/hr (as Hg)	19.653												
lb/MMBtu	6.47E-03												
lb/MMBtu	2.11E-05												

Note: <10% breakthrough is criteria in most cases

<10% RPD is criteria for paired trains in most cases

85%-115% average Spike recovery is Method 30B criteria

Low sample levels show more variation

**Montrose AQS**  
**Run 1 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 2**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA							
GENERAL				Impingers				dP		dP <sup>2</sup>	Temp	Velocity			
Test:	1-O2/CO2-U2			#/Matl.	End	Start	Diff.	Point	(in. H <sub>2</sub> O)	(in. H <sub>2</sub> O <sup>2</sup> )	(°F)	(fps)			
Date:	3/11/2021			1/H2O	827.2	734.2	93.0	5	0.97	0.9849	320	67.11			
Start Time:	10:20			2/H2O	749.5	740.5	9.0	4	0.92	0.9592	321	65.40			
Station:	Desert View Power			3/Empty	649.4	639.4	10.0	3	0.91	0.9539	321	65.04			
Unit:	Unit 2			4/S.G.	938.2	917.8	20.4	2	0.81	0.9000	322	61.41			
Test Condition:	Full Load			Rinse	0.0			1	0.73	0.8544	319	58.18			
Performed By:	DW			Total	132.4			5	0.93	0.9644	320	65.71			
PRE-TEST INFORMATION				Dry Gas Meter				4	0.91	0.9539	320	65.00			
SAMPLE TRAIN				Time	Vol.	Tm(in)	Tm(out)	3	0.82	0.9055	321	61.74			
Barom. Pressure:	psi			Start	815.050	78	79	2	0.79	0.8888	321	60.60			
	30.14 "Hg					79	80	1	0.76	0.8718	319	59.37			
Meter No.	23 wcs			Stop	858.300	80	80	5	1.00	1.0000	363	70.00			
Meter Y <sub>d</sub> :	1.0000					81	81	4	0.93	0.9644	363	67.50			
Meter Pressure:	2.0 iwg			Total	43.250	79.8		3	0.88	0.9381	359	65.50			
Pstack:	0.55 iwg			Summary				2	0.84	0.9165	359	64.00			
Pstack:	30.18 "Hg			Sample Volume:	42.820 dscf			1	0.80	0.8944	359	62.45			
Cp:	0.84			H <sub>2</sub> O Volume :	6.249 scf			5	0.85	0.9220	361	64.45			
Tref:	68 °F			Moisture Content:	12.7 %			4	0.83	0.9110	363	63.77			
Stack Area:	38.84 ft <sup>2</sup>							3	0.92	0.9592	364	67.18			
METHOD 3A, 6C, 7E DATA								2	0.98	0.9899	364	69.33			
<u>O<sub>2</sub></u> <u>CO<sub>2</sub></u>								1	0.99	0.9950	364	69.69			
Analyzer Span	19.15	18.94						5	1.20	1.0954	364	76.72			
Actual Span Value	10.78	10.56						4	0.95	0.9747	364	68.26			
Pre Test Zero Direct	0.00	0.00						3	0.92	0.9592	365	67.22			
Pre Test Span Direct	10.84	10.42						2	0.61	0.7810	363	54.67			
Pre-test Zero	0.11	0.06						1	0.63	0.7937	363	55.56			
Pre-test Span	10.87	10.39						5	0.96	0.9798	362	68.54			
Average	9.74	10.90						4	0.91	0.9539	362	66.73			
Post Test Zero Direct	-0.01	-0.03						3	0.84	0.9165	360	64.03			
Post Test Span Direct	10.84	10.38						2	1.00	1.0000	361	69.91			
Post-test Zero	0.00	0.01						1	1.10	1.0488	361	73.32			
Post-test Span	10.85	10.36						Average		0.8855	0.9410	348.3			
Average	9.74	10.90										65.28			
Corr. Results	9.66	11.09													
Cal Error <2%, Bias <5%; Drift <3%															
Calibration Error	0.3%	-0.7%													
Pre-Test Zero Bias	0.6%	0.3%													
Pre-Test Span Bias	0.1%	-0.1%													
Post-Test Zero Bias	0.0%	0.2%													
Post-Test Span Bias	0.1%	-0.1%													
Zero Drift	-0.6%	-0.2%													
Span Drift	-0.1%	-0.2%													

**Montrose AQS**  
**Run 2 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 2**

PRE-TEST INFORMATION				METHOD 4 DATA				METHOD 2 DATA				
GENERAL				Impingers				dP		dP <sup>2</sup>	Temp	Velocity
				#/Matl.	End	Start	Diff.	Point	(in. H <sub>2</sub> O)	(in. H <sub>2</sub> O <sup>2</sup> )	(°F)	(fps)
Test:	2-O2/CO2-U2			1/H2O	784.3	641.9	142.4	5	0.96	0.9798	320	66.95
Date:	3/11/2021			2/H2O	758.4	754.1	4.3	4	0.95	0.9747	321	66.65
Start Time:	11:40			3/Empty	598.6	597.7	0.9	3	0.90	0.9487	322	64.91
Station:	Desert View Power			4/S.G.	908.0	896.4	11.6	2	0.82	0.9055	322	61.96
Unit:	Unit 2			Rinse			0.0	1	0.77	0.8775	322	60.04
Test Condition:	Full Load			Total			159.2	5	0.93	0.9644	319	65.86
Performed By:	DW			Dry Gas Meter				4	0.81	0.9000	320	61.50
PRE-TEST INFORMATION				Time	Vol.	Tm(in)	Tm(out)	3	0.83	0.9110	321	62.30
Barom. Pressure:		psi		Start	858.400	81	83	2	0.82	0.9055	321	61.92
	30.14	"Hg				83	83	1	0.78	0.8832	320	60.35
Meter No.	23 wcs			Stop	905.100	82	83	5	1.20	1.0954	361	76.80
Meter Y <sub>d</sub> :	1.0000					83	83	4	1.20	1.0954	360	76.75
Meter Pressure:	2.0	iwg		Total	46.700		82.6	3	1.30	1.1402	361	79.94
Pstack:	0.55	iwg		Summary				2	1.40	1.1832	362	83.00
Pstack:	30.18	"Hg		Sample Volume:	45.991	dscf		1	1.00	1.0000	362	70.15
Cp:	0.84			H <sub>2</sub> O Volume :	7.514	scf		5	1.00	1.0000	363	70.19
Tref:	68	°F		Moisture Content:	14.0	%		4	0.93	0.9644	363	67.69
Stack Area:	38.84	ft <sup>2</sup>						3	0.88	0.9381	363	65.85
METHOD 3A, 6C, 7E DATA								2	0.85	0.9220	364	64.75
<u>O<sub>2</sub></u> <u>CO<sub>2</sub></u>								1	0.80	0.8944	364	62.82
Analyzer Span	19.15	18.94						5	0.85	0.9220	364	64.75
Actual Span Value	10.78	10.56						4	0.84	0.9165	364	64.37
Pre Test Zero Direct	-0.01	-0.03						3	0.92	0.9592	361	67.25
Pre Test Span Direct	10.84	10.38						2	0.97	0.9849	361	69.05
Pre-test Zero	0.00	0.01						1	0.99	0.9950	361	69.76
Pre-test Span	10.85	10.36						5	0.99	0.9950	362	69.80
Average	9.66	10.86						4	1.00	1.0000	362	70.15
								3	0.85	0.9220	362	64.68
Post Test Zero Direct	-0.02	-0.03						2	0.99	0.9950	360	69.71
Post Test Span Direc	10.80	10.36						1	1.10	1.0488	361	73.53
Post-test Zero	0.07	0.02						Average	0.9488	0.9741	348.3	67.78
Post-test Span	10.80	10.33										
Average	9.66	10.86										
Corr. Results	9.62	11.08										
Cal Error <2%, Bias <5%; Drift <3%												
Calibration Error	0.3%	-1.0%										
Pre-Test Zero Bias	0.0%	0.2%										
Pre-Test Span Bias	0.1%	-0.1%										
Post-Test Zero Bias	0.4%	0.3%										
Post-Test Span Bias	0.0%	-0.1%										
Zero Drift	0.4%	0.0%										
Span Drift	-0.3%	-0.2%										

**Montrose AQs**  
**Run 3 CEMS**  
**DATA AND WORKSHEET**  
**Desert View Power UNIT 2**

PRE-TEST INFORMATION		METHOD 4 DATA				METHOD 2 DATA									
GENERAL		Impingers				Point		dP (in. H <sub>2</sub> O)	dP <sup>2</sup> (in. H <sub>2</sub> O <sup>2</sup> )	Temp (°F)	Velocity (fps)				
Test:	3-O2/CO2-U2	#/Matl.	End	Start	Diff.		5	0.97	0.9849	322	67.09				
Date:	3/11/2021	1/H2O	868.0	754.0	114.0		4	0.95	0.9747	322	66.39				
Start Time:	13:15	2/H2O	747.9	744.5	3.4		3	0.93	0.9644	323	65.73				
Station:	Desert View Power	3/Empty	648.3	641.4	6.9		2	0.84	0.9165	323	62.47				
Unit:	Unit 2	4/S.G.	939.8	930.2	9.6		1	0.76	0.8718	323	59.42				
Test Condition:	Full Load	Rinse			0.0										
Performed By:	DW	Total			133.9										
PRE-TEST INFORMATION		Dry Gas Meter													
SAMPLE TRAIN		Time	Vol.	Tm(in)	Tm(out)										
Barom. Pressure:	30.14 "Hg	Start	905.600	80	82										
				80	82										
Meter No.	23 wcs	Stop	953.100	80	83										
Meter Y <sub>d</sub> :	1.0000			83	83										
Meter Pressure:	2.0 iwg	Total	47.500		81.6										
Summary															
Pstack:	0.55 iwg	Sample Volume:	46.865	dsfcf											
Pstack:	30.18 "Hg	H <sub>2</sub> O Volume :	6.320	scf											
Cp:	0.84	Moisture Content:	11.9	%											
Tref:	68 °F														
Stack Area:	38.84 ft <sup>2</sup>														
METHOD 3A, 6C, 7E DATA															
$O_2$		$CO_2$													
Analyzer Span	19.15	18.94													
Actual Span Value	10.78	10.56													
Pre Test Zero Direct	-0.02	-0.03													
Pre Test Span Direct	10.80	10.36													
Pre-test Zero	0.07	0.02													
Pre-test Span	10.80	10.33													
Average	9.75	10.76													
Post Test Zero Direct	-0.02	-0.02													
Post Test Span Direc	10.80	10.36													
Post-test Zero	0.06	0.04													
Post-test Span	10.83	10.31													
Average	9.75	10.76													
Corr. Results	9.72	11.01													
Cal Error <2%, Bias <5%; Drift <3%															
Calibration Error	0.1%	-1.1%													
Pre-Test Zero Bias	0.4%	0.3%													
Pre-Test Span Bias	0.0%	-0.1%													
Post-Test Zero Bias	0.4%	0.3%													
Post-Test Span Bias	0.2%	-0.3%													
Zero Drift	0.0%	0.1%													
Span Drift	0.2%	-0.1%													
TEST SUMMARY															
$O_2$ : 9.716 % dry															
8.562 % wet															
$CO_2$ : 11.013 % dry															
9.705 % wet															
$H_2O$ : 11.9 %															
MW: 28.71 lb/lb-mole															
Flow: 152,130 wacfm															
88.24 mdscfm															
5294.12 kdscfh															

Date	Start Time	End Time	Run #	Trap #	Spiked / Unspiked	Start Vol. I	Stop Vol. I	Total Vol. I	Total Vol. m3	Meter No.	Yd	delta H	Ref Temp	Vm std, dscm
3/11/2021	10:20	11:20	1-Hg-A	OLC137227	Unspiked	9346.307	9336.590	40.283	0.040283	1.4224	21-A	0.9989	30.14	0.04225
3/11/2021	10:20	11:20	1-Hg-B	OLC160774	Unspiked	3036.864	3077.064	40.200	0.040200	1.4195	21-B	0.9901	30.14	0.03881
3/11/2021	10:20	11:20	1-Hg-C	OLC139044	Unspiked	4953.190	4983.321	40.131	0.040131	1.4170	20-C	0.9989	30.14	0.04032
3/11/2021	10:20	11:20	1-Hg-S	OLC132337	Unspiked	3105.056	3145.328	40.272	0.040272	1.4220	20-S	0.9993	30.14	0.04047
3/11/2021	11:40	12:40	2-Hg-A	OLC149000	Unspiked	9387.415	9427.615	40.200	0.040200	1.4195	21-A	0.9989	30.14	0.04024
3/11/2021	11:40	12:40	2-Hg-B	OLC148880	Unspiked	3077.826	3117.900	40.074	0.040074	1.4150	21-B	0.9901	30.14	0.03975
3/11/2021	11:40	12:40	2-Hg-C	OLC149014	Unspiked	4994.405	5034.530	40.125	0.040125	1.4168	20-C	0.9989	30.14	0.04010
3/11/2021	11:40	12:40	2-Hg-S	OLC131609	Spiked	3146.130	3186.325	40.195	0.040195	1.4193	20-S	0.9993	30.14	0.04019
3/11/2021	13:15	14:15	3-Hg-A	OLC160618	Unspiked	9428.565	9468.950	40.385	0.040385	1.4260	21-A	0.9989	30.14	0.04030
3/11/2021	13:15	14:15	3-Hg-B	OLC131666	Unspiked	3136.734	3176.956	40.222	0.040222	1.4202	21-B	0.9901	30.14	0.03971
3/11/2021	13:15	14:15	3-Hg-C	OLC160765	Unspiked	5035.724	5075.824	40.100	0.040100	1.4159	20-C	0.9989	30.14	0.04005
3/11/2021	13:15	14:15	3-Hg-S	OLC131647	Spiked	3186.907	3227.250	40.343	0.040343	1.4245	20-S	0.9993	30.14	0.04031

Run: 1-Hg-B

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePresActual A	OfficePresActual C	StackTerm pA	StackTe mpB	Probe Temp C	TrapTemp A	TrapTemp B	Dry Gas C	Pump Vac D	Sample Rate D	Sample Rate B	Notes
0	10	10:20:00 AM	9346.307	3036.884	n/a	0	0	0	319	319	233	233	233	70	1	0.7	0.7	
10	20	10:30:00 AM	9353.021	3043.564	n/a	0	0	0	319	319	245	245	245	70	1	0.7	0.7	
20	30	10:40:00 AM	9359.735	3059.254	n/a	0	0	0	319	319	300	300	300	72	1	0.7	0.7	
30	40	10:50:00 AM	9366.449	3066.964	n/a	0	0	0	319	319	303	303	303	72	1	0.7	0.7	
40	50	11:00:00 AM	9373.162	3063.665	n/a	0	0	0	319	319	302	302	302	73	1	0.7	0.7	
50	60	11:10:00 AM	9379.876	3070.364	n/a	0	0	0	319	319	302	302	302	73	1	0.7	0.7	
60	70	11:20:00 AM	9386.590	3077.064														

Run: 1-Hg-C

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePresActual A	OfficePresActual C	StackTerm pA	StackTe mpB	Probe Temp C	TrapTemp A	TrapTemp B	Dry Gas C	Pump Vac D	Sample Rate D	Sample Rate B	Notes
0	10	10:20:00 AM	9346.307	3036.884	n/a	0	0	0	319	319	233	233	233	68	1	0.7	0.7	
10	20	10:30:00 AM	9353.021	3043.564	n/a	0	0	0	319	319	245	245	245	68	1	0.7	0.7	
20	30	10:40:00 AM	9359.735	3059.254	n/a	0	0	0	319	319	300	300	300	68	1	0.7	0.7	
30	40	10:50:00 AM	9366.449	3066.964	n/a	0	0	0	319	319	303	303	303	69	1	0.7	0.7	
40	50	11:00:00 AM	9373.162	3063.665	n/a	0	0	0	319	319	302	302	302	69	1	0.7	0.7	
50	60	11:10:00 AM	9379.876	3070.364	n/a	0	0	0	319	319	302	302	302	70	1	0.7	0.7	
60	70	11:20:00 AM	9386.590	3077.064														

Run: 1-Hg-S

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePresActual A	OfficePresActual C	StackTerm pA	StackTe mpB	Probe Temp C	TrapTemp A	TrapTemp B	Dry Gas C	Pump Vac D	Sample Rate D	Sample Rate B	Notes
0	10	10:20:00 AM	9346.307	3036.884	n/a	0	0	0	319	319	233	233	233	68	1	0.7	0.7	
10	20	10:30:00 AM	9353.021	3043.564	n/a	0	0	0	319	319	245	245	245	68	1	0.7	0.7	
20	30	10:40:00 AM	9359.735	3059.254	n/a	0	0	0	319	319	300	300	300	68	1	0.7	0.7	
30	40	10:50:00 AM	9366.449	3066.964	n/a	0	0	0	319	319	303	303	303	69	1	0.7	0.7	
40	50	11:00:00 AM	9373.162	3063.665	n/a	0	0	0	319	319	302	302	302	69	1	0.7	0.7	
50	60	11:10:00 AM	9379.876	3070.364	n/a	0	0	0	319	319	302	302	302	70	1	0.7	0.7	
60	70	11:20:00 AM	9386.590	3077.064														

Run: 2-Hg-A

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePresActual A	OfficePresActual C	StackTerm pA	StackTe mpB	Probe Temp C	TrapTemp A	TrapTemp B	Dry Gas C	Pump Vac D	Sample Rate D	Sample Rate B	Notes
0	10	10:20:00 AM	9346.307	3036.884	n/a	0	0	0	319	319	233	233	233	68	1	0.7	0.7	
10	20	10:30:00 AM	9353.021	3043.564	n/a	0	0	0	319	319	245	245	245	68	1	0.7	0.7	
20	30	10:40:00 AM	9359.735	3059.254	n/a	0	0	0	319	319	300	300	300	68	1	0.7	0.7	
30	40	10:50:00 AM	9366.449	3066.964	n/a	0	0	0	319	319	303	303	303	69	1	0.7	0.7	
40	50	11:00:00 AM	9373.162	3063.665	n/a	0	0	0	319	319	302	302	302	69	1	0.7	0.7	
50	60	11:10:00 AM	9379.876	3070.364	n/a	0	0	0	319	319	302	302	302	70	1	0.7	0.7	
60	70	11:20:00 AM	9386.590	3077.064														

Run: 2-Hg-C

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePresActual A	OfficePresActual C	StackTerm pA	StackTe mpB	Probe Temp C	TrapTemp A	TrapTemp B	Dry Gas C	Pump Vac D	Sample Rate D	Sample Rate B	Notes
0	10	10:20:00 AM	9346.307	3036.884	n/a	0	0	0	319	319	233	233	233	68	1	0.7	0.7	
10	20	10:30:00 AM	9353.021	3043.564	n/a	0	0	0	319	319	245	245	245	68	1	0.7	0.7	
20	30	10:40:00 AM	9359.735	3059.254	n/a	0	0	0	319	319	300	300	300	68	1	0.7	0.7	
30	40	10:50:00 AM	9366.449	3066.964	n/a	0	0	0	319	319	303	303	303	69	1	0.7	0.7	
40	50	11:00:00 AM	9373.162	3063.665	n/a	0	0	0	319	319	302	302	302	69	1	0.7	0.7	
50	60	11:10:00 AM	9379.876	3070.364	n/a	0	0	0	319	319	302	302	302	70	1	0.7	0.7	
60	70	11:20:00 AM	9386.590	3077.064														

Run: 2-Hg-S

Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePresActual A	OfficePresActual C	StackTerm pA	StackTe mpB	Probe Temp C	TrapTemp A	TrapTemp B	Dry Gas C	Pump Vac D	Sample Rate D	Sample Rate B	Notes
0	10	10:20:00 AM	9346.307	3036.884	n/a	0	0	0	319	319	233	233	233	68	1	0.7	0.7	
10	20	10:30:00 AM	9353.021	3043.564	n/a	0	0	0	319	319	245	245	245	68	1	0.7	0.7	
20	30	10:40:00 AM	9359.735	3059.254	n/a													

50	60	12:30:00 PM	5027.843	3179.624	n/a	0	0	321	321	301	301	301	301	1	0.7	0.7				
60		12:40:00 PM	5034.530	3186.325																
<b>Run:</b> 3-Hg-B																				
Point	BeginTime	EndTime	Clock	GasMeterA	GasMeterB	DeltaP	OfficePresA actual A	OfficePresA Actual B	StackTem mpA	Probe Temp A	Probe Temp B	TrapTemp A	TrapTemp B	Dry Gas A	Dry Gas B	Pump Vac A	Pump Vac B	Sample Rate A	Sample Rate B	Notes
0	10	1:15:00 PM	9428.565	3136.734	n/a	0	0	0	323	300	300	300	300	72	73	1	1	0.7	0.7	
10	20	1:25:00 PM	9435.291	3145.438	n/a	0	0	0	323	300	300	300	300	73	73	1	1	0.7	0.7	
20	30	1:35:00 PM	9442.026	3150.140	n/a	0	0	0	323	300	300	300	300	74	74	1	1	0.7	0.7	
30	40	1:45:00 PM	9448.757	3156.445	n/a	0	0	0	323	302	302	302	302	72	74	1	1	0.7	0.7	
40	50	1:55:00 PM	9455.487	3163.550	n/a	0	0	0	323	302	302	302	302	72	73	1	1	0.7	0.7	
50	60	2:05:00 PM	9462.218	3170.252	n/a	0	0	0	322	302	302	302	302	72	73	1	1	0.7	0.7	
60		2:15:00 PM	9468.950	3176.956																

0	10	1:15:00 PM	5035.724	3186.907	n/a	0	0	0	323	300	300	300	300	71	71	1	1	0.7	0.7
10	20	1:25:00 PM	5042.407	3193.625	n/a	0	0	0	323	300	300	300	300	72	72	1	1	0.7	0.7
20	30	1:35:00 PM	5049.091	3200.350	n/a	0	0	0	323	300	300	300	300	72	72	1	1	0.7	0.7
30	40	1:45:00 PM	5065.772	3207.080	n/a	0	0	0	323	302	302	302	302	72	72	1	1	0.7	0.7
40	50	1:55:00 PM	5062.560	3213.815	n/a	0	0	0	323	302	302	302	302	72	72	1	1	0.7	0.7
50	60	2:05:00 PM	5069.141	3220.555	n/a	0	0	0	322	302	302	302	302	72	72	1	1	0.7	0.7
60		2:15:00 PM	5075.324	3227.250															

W002AS-006514-R1